

APPENDIX D

SUPPORTING DATA FOR MOST STRINGENT EMISSION LIMITS FOR PROCESS EQUIPMENT AT BIOREFINERIES

Table Notes:

- (1) Calculated values, in *italics*, are shown for comparative purposes.
- (2) Calculated VOC values are calculated as methane unless otherwise specified.
- (3) N/A indicates that BACT was not triggered, or the rule, guideline, or policy does not cover that particular pollutant.
- (4) F factor for waste gas is assumed to be 9,570 dscf/MMBtu.
- (5) Efficiency for reciprocating IC engines is assumed to be 35%.
- (6) SCAQMD BACT Clearinghouse is organized such that guidelines for non-major facilities are contained in Part D and guidelines for major facilities are included in Part B. For major sources in the District, the project proponent should not automatically assume it will meet District BACT requirements if proposed emission levels are consistent with Part D guidelines. The project proponent should check the Part B guidelines and consult with District permitting staff.

| Table D-1. Grain Receiving, Conveying, Grinding, and Storage Operations | | | | | | | | | | |
|--|--------------------------------------|---|----------------------|------------------|------------------------------------|---------------------|----|-----|-----------------|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Pacific Ethanol; Brawley, CA | Biomass fuel receiving, handling, and storage | | Permit | 2007 | | | | | Baghouse w/ 99% control |
| 2 | SJVAPCD Guideline 6.4.5 ¹ | Biomass fuel receiving, handling, and storage | | BACT (AIP) | 9/7/1998 | | | | | Use of wet suppression system on all emission units, transfer points, and raw material stockpiles to maintain moisture to prevent visible emissions >20% |

¹ Based on Chrysler Corp., Mendota, CA.

| Table D-1. Grain Receiving, Conveying, Grinding, and Storage Operations | | | | | | | | | | |
|--|--|--|----------------------|------------------|------------------------------------|---------------------|----|-----|-----------------|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 3 | SCAQMD Guidelines for Non-Major Facilities | Bulk solid material handling – other (feed and grain handling) | | BACT | 1988 | | | | | Baghouse |
| 4 | SCAQMD Guidelines for Non-Major Facilities | Bulk solid material handling – other (pneumatic conveying, except paper and fiber) | | BACT | 1988 | | | | | Baghouse |
| 5 | SCAQMD Guidelines for Non-Major Facilities | Bulk solid material handling – other (other dry materials handling) | | BACT | 7/11/1997 | | | | | Enclosed conveyors and baghouse |
| 6 | SCAQMD Guidelines for Non-Major Facilities | Bulk solid material handling – other (other wet materials handling) | | BACT | 1988 | | | | | Water spray or adequate material moisture |

| Table D-2. Methanol/Sodium Methoxide Receiving and Storage | | | | | | | | | | |
|---|--|-----------------|-----------------------|------------------|------------------------------------|---------------------|----|---------------|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | American Biodiesel, Inc. dba Community Fuels; Stockton, CA | | Vapor recovery system | Permit | 6/4/2007 | | | 99.5% control | | |
| 2 | Blue Sky Bio-Fuel, Inc.; Oakland, CA | | Vapor balance system | Permit | | | | 95% control | | |
| 3 | Crimson Renewable Energy, LP; Bakersfield CA | | Vapor control system | Permit | 12/13/2008 | | | 95% control | | |

Table D-2. Methanol/Sodium Methoxide Receiving and Storage

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|----------|---|-----------------|----------------------|------------------|------------------------------------|---------------------|----|-------------|-----------------|------|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 4 | Golden Gate Petroleum Company; San Jose, CA | | Vapor balance system | Permit | | | | 95% control | | |

Table D-3. Fermentation Process: Yeast, Liquefaction, Beerwell, and Process Condensate Tanks

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|----------|---|--|--|------------------|------------------------------------|---------------------|----|--|-----------------|------|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Pacific Ethanol; Madera, CA | Ethanol fermentation process tanks | Wet scrubber to Regenerative Thermal Oxidizer | Source test | 2/20/2007 | | | >99.9% control | | |
| 2 | Phoenix Bio Industries, LLC; Goshen, CA | Ethanol fermentation process tanks including fermentation tanks and beerwell storage tanks | Wet scrubber vented to CO ₂ wet scrubber w/ Regenerative Thermal Oxidizer | Source test | 4/18/2007 | | | 99.7% control | | |
| 3 | SJVAPCD Guideline 4.12.4 ² | Ethanol fermentation process tanks including fermentation tanks and beerwell storage tanks | | BACT (AIP) | 2/17/2004 | | | 99.5% VOC control efficiency (fermentation wet scrubber vented to CO ₂ recovery plant w/ condenser and high pressure scrubber, or equivalent) | | |

² Based on Pacific Ethanol, Madera, CA.

| Table D-4. Distillation and Wet Cake Processes | | | | | | | | | | |
|--|---------------------------------------|--|--|------------------------|---|---------------------|----|--------------------|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Pacific Ethanol; Madera, CA | Ethanol distillation process | Distillation wet scrubber | Source test | 2/20/2007 | | | >99% control | | |
| 2 | Calgren Renewable Fuels; Pixley, CA | Emissions units involved in ethanol distillation and wet cake process (excluding wet cake dryer) | Distillation wet scrubber w/ regenerative thermal oxidizer | Authority to Construct | 7/7/2005 | | | 95% VOC control | | |
| 3 | Calgren Renewable Fuels; Pixley, CA | Emissions units involved in ethanol distillation and wet cake process (excluding wet cake dryer) | Distillation wet scrubber w/ regenerative thermal oxidizer | Source test | 1/12/2010 | | | >99.9% VOC control | | |
| 4 | Pacific Ethanol; Madera, CA | Emissions units involved in ethanol wet cake process (excluding wet cake dryer) | Distillation wet scrubber | Permit | (Authority to Construct issued in 2005) | | | 95% control | | |
| 5 | Pacific Ethanol; Madera, CA | Emissions units involved in ethanol wet cake process (excluding wet cake dryer) | Distillation wet scrubber | Source test | 1/25/2008 | | | >99% control | | |
| 6 | SJVAPCD Guideline 4.12.5 ³ | Emissions units involved in ethanol distillation and wet cake process (excluding wet cake dryer) | Wet scrubber or equivalent | BACT (AIP) | 2/17/2004 | | | 95% VOC control | | |

³ Based on Pacific Ethanol, Madera, CA.

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|--|-------------------------------------|----------------------|------------------|------------------------------------|---|--|---|-----------------|----------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SJVAPCD Rule 4307 Boilers, Steam Generators, and Process Heaters – 2.0 MMBtu/hr to 5.0 MMBtu/hr | Units 2.0 MMBtu/hr to ≤5.0 MMBtu/hr | | Rule | Last amended 10/16/2008 | Atmospheric units: 12 ppmvd @ 3% O ₂ or 0.014 lb/MMBtu Non-atmospheric units: 9 ppmvd @ 3% O ₂ or 0.011 lb/MMBtu | 400 ppmvd @ 3% O ₂ (0.296 lb/MMBtu) | N/A | N/A | N/A |
| 2 | SCAQMD Rule 1146.1 Emissions of Oxides of Nitrogen from Small Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters | Units >2 MMBtu/hr to <5 MMBtu/hr | | Rule | Last amended 9/5/2008 | Atmospheric units: 12 ppm @ 3% O ₂ or 0.015 lb/MMBtu Non-atmospheric units: 9 ppmvd @ 3% O ₂ or 0.011 lb/MMBtu | N/A | N/A | N/A | N/A |
| 3 | La Paloma Generating Company, LLC; McKittrick, CA | 6.2 MMBtu/hr natural gas boiler | Low NOx burner | BACT (AIP) | 3/24/2000 | 12 ppmv @ 3% O ₂ (0.0146 lb/MMBtu) | 50 ppmv @ 3% O ₂ (0.037 lb/MMBtu) | 30 ppmv @ 3% O ₂ (0.0127 lb/MMBtu) | N/A | 0.007 lb/MMBtu |

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|---|---|--------------------------------|------------------|---|---|--|-----|-----------------|-------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 4 | SJVAPCD Rule 4306 Boilers, Steam Generators, and Process Heaters – Phase 3 | Units >5 MMBtu/hr to ≤20.0 MMBtu/hr (non-refinery units, non-load following units, units not subject to fuel use restriction) | | Rule | Last amended 10/16/2008 | Standard Option: 15 ppmvd @ 3% O ₂ or 0.018 lb/MMBtu Enhanced Option: 9 ppmvd @ 3% O ₂ or 0.011 lb/MMBtu | 400 ppmvd @ 3% O ₂ (0.296 lb/MMBtu) | N/A | N/A | N/A |
| 5 | SCAQMD BACT Guidelines – Part D | <20 MMBtu/hr natural gas or propane fired boiler | Ultra low NOx burner, or equal | BACT | 10/20/2000 (NOx, SOx), 4/10/1998 (CO, PM10) | ≤12 ppmvd @ 3% O ₂ (0.015 lb/MMBtu) | Firetube type: ≤50 ppmvd @ 3% O ₂ (0.037 lb/MMBtu) Watertube type: ≤100 ppmvd @ 3% O ₂ (0.074 lb/MMBtu) | N/A | Natural gas | Natural gas |
| 6 | BAAQMD Regulation 9 Rule 7 NOx and CO from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters | 20 MMBtu/hr to <75 MMBtu/hr gaseous fuel-fired boiler | | Rule | Last amended 7/30/2008 | 9 ppmvd @ 3% O ₂ (0.011 lb/MMBtu) | 400 ppmvd @ 3% O ₂ (0.296 lb/MMBtu) | N/A | N/A | N/A |

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|--|--|---|------------------|---|---|--|-----|-----------------|-------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 7 | SJVAPCD Rule 4306 Boilers, Steam Generators, and Process Heaters – Phase 3 | Units >20.0 MMBtu/hr (non-refinery units, non-load following units, units not subject to fuel use restriction) | | Rule | Last amended 10/16/2008 | Standard Option: 9 ppmvd @ 3% O ₂ or 0.011 lb/MMBtu Enhanced Option: 6 ppmvd @ 3% O ₂ or 0.007 lb/MMBtu | 400 ppmvd @ 3% O ₂ (0.296 lb/MMBtu) | N/A | N/A | N/A |
| 8 | SCAQMD BACT Guidelines – Part D | ≥20 MMBtu/hr natural gas or propane fired boiler | Ultra low NOx burner or equal; SCR or equal | BACT | 10/20/2000 (NOx, SOx), 4/10/1998 (CO, PM10) | With low NOx burner: ≤9 ppmvd @ 3% O ₂ (0.011 lb/MMBtu) With add-on controls: ≤7 ppmvd @ 3% O ₂ (0.009 lb/MMBtu) NH ₃ : ≤5 ppmvd @ 3% O ₂ | Firetube type: ≤50 ppmvd @ 3% O ₂ (0.037 lb/MMBtu) Watertube type: ≤100 ppmvd @ 3% O ₂ (0.074 lb/MMBtu) | N/A | Natural gas | Natural gas |
| 9 | SJVAPCD (Facility unknown) | >20 MMBtu/hr natural gas fired boiler | Ultra low NOx burner or equal | BACT (AIP) | 6/30/1999 | 9 ppmv @ 3% O ₂ or 0.0108 lb/MMBtu | N/A | N/A | N/A | N/A |

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|-------------------------------|--------------------------------|----------------------|------------------|------------------------------------|---|---|------------------|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NO _x | CO | VOC | SO ₂ | PM ₁₀ |
| 10 | SJVAPCD (Facility unknown) | ≥5 MMBtu/hr steam generator | | BACT (AIP) | 5/24/2004 | 14 ppmv @ 3% O ₂ (0.017 lb/MMBtu) | 50 ppmv @ 3% O ₂ (0.037 lb/MMBtu) | Gaseous fuels | Natural gas, LPG, waste gas treated to remove 95% by weight of sulfur compounds or treated such that the sulfur content does not exceed 1 gr/100 scf, or use of a continuously operating SO ₂ scrubber and either achieving 95% by weight control of sulfur compounds or achieving an emission rate of 30 ppmvd SO ₂ at stack O ₂ | Natural gas, LPG, waste gas treated to remove 95% by weight of sulfur compounds or treated such that the sulfur content does not exceed 1 gr/100 scf, or use of a continuously operating SO ₂ scrubber and either achieving 95% by weight control of sulfur compounds or achieving an emission rate of 30 ppmvd SO ₂ at stack O ₂ |

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|--|--|--|-----------------------|------------------------------------|---|--|--|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 11 | BAAQMD BACT Guideline 17.3.1 | ≥50 MMBtu/hr | Ultra low NOx burner + FGR, good combustion practice | BACT (AIP) | 9/22/2005 | 9 ppmvd @ 3% O ₂ (0.011 lb/MMBtu) | 50 ppmv @ 3% O ₂ (0.037 lb/MMBtu) | N/A | Natural gas or treated refinery gas fuel w/ <100 ppmv total reduced sulfur | Natural gas or treated refinery gas fuel |
| | | | SCR + low NOx burners + FGR, oxidation catalyst | BACT (tech. feasible) | | 7 ppmvd @ 3% O ₂ (0.009 lb/MMBtu) | For units ≥250 MMBtu/hr: 10 ppmvd @ 3% O ₂ ⁴ (0.007 lb/MMBtu) | | | |
| 12 | SCAQMD Rule 1146 Emissions of Oxides of Nitrogen from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters | Units ≥5 MMBtu/hr (excluding electric utility boilers, >40 MMBtu/hr boilers and process heaters used in petroleum refineries, sulfur plant reaction boilers) | | Rule | Last amended 9/5/2008 | ≥5 to <75 MMBtu/hr: 9 ppm @ 3% O ₂ or 0.011 lb/MMBtu ≥75 MMBtu/hr: 5 ppm @ 3% O ₂ or 0.0062 lb/MMBtu | N/A | N/A | N/A | N/A |
| 13 | CalResources; Western Kern County Oil Fields, CA | 62.5 MMBtu/hr natural gas boiler | FGR and O ₂ controller | BACT (AIP) | 11/30/1993 | 0.036 lb/MMBtu (30 ppmvd @ 3% O ₂) | 0.02 lb/MMBtu (27 ppmvd @ 3% O ₂) | 0.003 lb/MMBtu (7 ppmvd @ 3% O ₂) | 0.0006 lb/MMBtu | 0.005 lb/MMBtu |

⁴ CO limit does not apply to boilers smaller than 250 MMBtu/hr unless an oxidation catalyst is found to be cost effective or is necessary for TBACT or VOC control.

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|---|---|---|--|------------------------------------|---|---|---|---|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 14 | BAAQMD Regulation 9 Rule 7 NOx and CO from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters | ≥75 MMBtu/hr gaseous fuel-fired boiler | | Rule | Last amended 7/30/2008 | 5 ppmvd @ 3% O ₂ (0.006 lb/MMBtu) | 400 ppmvd @ 3% O ₂ (0.296 lb/MMBtu) | N/A | N/A | N/A |
| 15 | Berry Petroleum; Heavy Oil Central, SJVAPCD, CA | 84 MMBtu/hr boiler | SCR, low NOx burner | BACT (AIP): SOx, PM10, VOC BACT (tech. feasible): NOx | 3/11/2005 | With SCR: 7 ppmvd @ 3% O ₂ (0.009 lb/MMBtu); With low NOx burner: 9 ppmvd @ 3% O ₂ (0.0109 lb/MMBtu) | N/A | Natural gas, treated waste gas or recovered gas as a primary fuel. LPG as backup fuel | Natural gas, treated waste gas or recovered gas as a primary fuel. LPG as backup fuel | Natural gas, treated waste gas or recovered gas as a primary fuel. LPG as backup fuel |
| 16 | Genentech, Inc.; San Mateo, CA | 97 MMBtu/hr Nebraska Model NS-E-64-ST-CA-HM-AL natural gas watertube boiler | Ultra low NOx burner | BACT | 9/27/2005 (startup: 6/14/2006) | 9 ppmvd @ 3% O ₂ (0.011 lb/MMBtu) | 50 ppmv @ 3% O ₂ (0.037 lb/MMBtu) | N/A | N/A | N/A |
| 17 | AES Huntington Beach; Huntington Beach, CA | 2,088 MMBtu/hr natural gas boiler | Low NOx burners, FGR, SCR, oxidation catalyst | BACT (AIP) | 2/1/2006 | 5 ppmvd @ 3% O ₂ (0.006 lb/MMBtu) | 5 ppmvd @ 3% O ₂ (0.004 lb/MMBtu) | 1354 lb/mo | 0.2 lb/MMBtu (120 ppmvd @ 3% O ₂) | 0.01 gr/scf @ 12% CO ₂ |

| Table D-5. Natural Gas-Fired Boiler | | | | | | | | | | |
|-------------------------------------|--|---|----------------------|------------------|------------------------------------|---|--|-----|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 18 | SJVAPCD Rule 4320 Advanced Emission Reduction Options for Boilers, Steam Generators, and Process Heaters with a Total Rated Heat Input Greater than 5.0 MMBtu/hr | Units >5.0 to ≤20.0 MMBtu/hr ⁵ | | Rule | 10/16/2008 | Standard Schedule: 9 ppmvd @ 3% O ₂ or 0.011 lb/MMBtu | 400 ppmvd @ 3% O ₂ (0.296 lb/MMBtu) | N/A | N/A | N/A |
| | | Units >20.0 MMBtu/hr | | | | Enhanced Schedule: 6 ppmvd @ 3% O ₂ or 0.007 lb/MMBtu | | | | |
| | | | | | | Standard Schedule: 7 ppmvd @ 3% O ₂ or 0.008 lb/MMBtu | | | | |
| | | | | | | Enhanced Schedule: 5 ppmvd @ 3% O ₂ or 0.0062 lb/MMBtu | | | | |

⁵ The NOx limits listed here do not apply to oilfield steam generators, refinery units, units with fuel use restrictions, units at wastewater treatment facilities firing on <50% by volume PUC quality gas, and units operated by a small producer where each burner <5 MMBtu/hr but the total rating is 5-20 MMBtu/hr. See rule for additional restrictions.

| Table D-6. Biomass-Fired Boiler | | | | | | | | | | |
|---------------------------------|---|--|--|------------------------|------------------------------------|--|---|--|--|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Musco Olive Products; Tracy, CA | 25 MMBtu/hr combined Solar Technologies Model Steamboy fluidized bed boiler producing 3 MW | FGR, SCR, catalyst PM control system (cyclone or in-line bag filter upstream of SCR), baghouse | Authority to Construct | 10/2/2009 | 17.5 ppmvd @ 3% O ₂ (0.023 lb/MMBtu) NH ₃ slip: 10 ppmvd @ 3% O ₂ | 183 ppmvd @ 3% O ₂ (0.144 lb/MMBtu) | 0.02 lb/MMBtu (45 ppm @ 3% O ₂) | 23 ppmvd @ 3% O ₂ (0.041 lb/MMBtu) | 0.045 lb/MMBtu (0.002 gr/scf @ 12% CO ₂) |
| 2 | Massachusetts Department of Environmental Protection BACT Guidance for Biomass Projects | Solid biomass fuel-fired steam electric generating units, ≥1 to <10 MW | | BACT (AIP) | 4/18/2007 ⁶ | 0.093 lb/MMBtu (72 ppm @ 3% O ₂) NH ₃ slip: 25 ppm @ 3% O ₂ | 0.25 lb/MMBtu (320 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.025 lb/MMBtu (14 ppm @ 3% O ₂) | Filterable: 0.012 lb/MMBtu (0.006 gr/scf @ 12% CO ₂) |
| | | | | BACT (tech. feasible) | | 0.093 lb/MMBtu (72 ppm @ 3% O ₂) NH ₃ slip: 10 ppm @ 3% O ₂ | 0.25 lb/MMBtu (320 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.02 lb/MMBtu (11 ppm @ 3% O ₂) | Filterable: 0.012 lb/MMBtu (0.006 gr/scf @ 12% CO ₂) |

⁶ The guidance indicates it expired on December 31, 2009, and prior to expiration, MassDEP would review its experience with the guidance and initiate a public discussion to determine next steps, such as affirming and/or revising the guidance, or proposing regulations to codify biomass performance standards. According to MassDEP staff, other matters have taken precedence and the public process to update or revise the guidance has not been initiated. However, the guidance is still valid and continues to be available to the public on the MassDEP website at: <http://www.mass.gov/dep/air/laws/policies.htm>.

| Table D-6. Biomass-Fired Boiler | | | | | | | | | | |
|---------------------------------|---|--|----------------------|-----------------------|------------------------------------|--|---|---|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 3 | Rio Bravo; Fresno, CA | 352 MMBtu/hr circulating fluidized bed boiler with steam turbine producing 24.3 MW | SNCR, ESP | Permit | 2009 | 0.08 lb/MMBtu (62 ppmvd @ 3% O ₂); 27.5 lb/hr | 22.0 lb/hr; 0.06 lb/MMBtu ; 400 ppmv @ 3% O ₂ ; 310 ppmv @ 12% CO ₂ and 7% O ₂ | 10.4 lb/hr; 0.03 lb/MMBtu | 10.0 lb/hr; 0.2% by volume | Filterable: 0.01 gr/dscf @ 12% CO ₂ ; 5.8 lb/hr, 0.02 lb/MMBtu Condensable : 17.4 lb/hr; 0.05 lb/MMBtu |
| 4 | Massachusetts Department of Environmental Protection BACT Guidance for Biomass Projects | Solid biomass fuel-fired steam electric generating units, ≥10 to <25 MW | | BACT (AIP) | 4/18/2007 | 0.075 lb/MMBtu (58 ppm @ 3% O ₂) NH ₃ slip: 13 ppm @ 3% O ₂ | 0.17 lb/MMBtu (220 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.025 lb/MMBtu (14 ppm @ 3% O ₂) | Filterable: 0.012 lb/MMBtu (0.006 gr/scf @ 12% CO ₂) |
| | | | | BACT (tech. feasible) | | 0.015 lb/MMBtu (12 ppm @ 3% O ₂) NH ₃ slip: 2 ppm @ 3% O ₂ | 0.01 lb/MMBtu (13 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.02 lb/MMBtu (11 ppm @ 3% O ₂) | Filterable: 0.012 lb/MMBtu (0.006 gr/scf @ 12% CO ₂) |

| Table D-6. Biomass-Fired Boiler | | | | | | | | | | |
|---------------------------------|---|---|--|------------------------|------------------------------------|---|---|--|---|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 5 | Massachusetts Department of Environmental Protection BACT Guidance for Biomass Projects | Solid biomass fuel-fired steam electric generating units, ≥25 MW | | BACT (AIP) | 4/18/2007 | 0.075 lb/MMBtu (58 ppm @ 3% O ₂) NH ₃ slip: 13 ppm @ 3% O ₂ | 0.1 lb/MMBtu (128 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.025 lb/MMBtu (14 ppm @ 3% O ₂) | Filterable: 0.012 lb/MMBtu (0.006 gr/scf @ 12% CO ₂) |
| | | | | BACT (tech. feasible) | | 0.015 lb/MMBtu (12 ppm @ 3% O ₂) NH ₃ slip: 2 ppm @ 3% O ₂ | 0.01 lb/MMBtu (13 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.02 lb/MMBtu (11 ppm @ 3% O ₂) | Filterable: 0.012 lb/MMBtu (0.006 gr/scf @ 12% CO ₂) |
| 6 | Valley Bio-Energy; Modesto, CA | 402 MMBtu/hr McBurney Corporation biomass-fired boiler with Detroit stoker vibrating grate feeder serving a steam turbine producing 33 MW (gross) | SNCR, SCR, dry powder scrubber w/ trona injection, multiclone, ESP | Authority to Construct | | 0.012 lb/MMBtu (24-hr block avg.) ⁷ (9 ppm @ 3% O ₂) NH ₃ slip: 50 ppmvd @ 3% O ₂ | 0.046 lb/MMBtu (24-hr block avg.) (59 ppm @ 3% O ₂) | 0.005 lb/MMBtu (11 ppm @ 3% O ₂) | 0.012 lb/MMBtu (1-hr avg.) (7 ppm @ 3% O ₂) | 0.024 lb/MMBtu (0.011 gr/scf @ 12% CO ₂) |

⁷ This limit is subject to a 12-month evaluation period to assess the operational variability and optimum control effectiveness of the emission control system to meet the target emission limit. In no event shall emissions exceed 0.065 lb/MMBtu (3-hr rolling avg.), except during startup and shutdown.

| Table D-6. Biomass-Fired Boiler | | | | | | | | | | |
|---------------------------------|--|--|--|------------------------|------------------------------------|---|--|--|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 7 | SJVAPCD BACT analysis for San Joaquin Solar 1 & 2 | (4) 425 MMBtu/hr Energy Products of Idaho (EPI) fluidized bubbling bed boiler with (1) 15 MMBtu/hr and (3) 50 MMBtu/hr natural gas-fired startup burners serving two steam turbines producing 53.4 MW each | RSCR or equal, limestone injection, baghouse or ESP, natural gas auxiliary fuel | BACT (AIP) | 10/8/2009 | 0.075 lb/MMBtu (58 ppm @ 3% O ₂) | 0.1 lb/MMBtu (128 ppm @ 3% O ₂) | 0.01 lb/MMBtu (22 ppm @ 3% O ₂) | 0.025 lb/MMBtu (14 ppm @ 3% O ₂) | 0.045 lb/MMBtu (0.002 gr/scf @ 12% CO ₂) |
| | | | Option 1: SNCR + SCR + wet scrubber or equal, limestone injection, baghouse + multiclones+ wet scrubber or equal, natural gas auxiliary fuel Option 2: SCR or equal, limestone injection, baghouse + multiclones+ wet scrubber or equal, natural gas auxiliary fuel | BACT (tech. feasible) | | Option 1: 0.012 lb/MMBtu (9 ppm @ 3% O ₂) Option 2: 0.065 lb/MMBtu (50 ppm @ 3% O ₂) | 0.046 lb/MMBtu (59 ppm @ 3% O ₂) | 0.005 lb/MMBtu (11 ppm @ 3% O ₂) | 0.012 lb/MMBtu (7 ppm @ 3% O ₂) | 0.024 lb/MMBtu (0.011 gr/scf @ 12% CO ₂) |
| 8 | Wheelabrator; Delano, CA (changed name to AES Delano) | 400 MMBtu/hr circulating fluidized bed boiler with steam turbine producing 31 MW | SNCR, limestone injection, sodium bicarbonate injection, multiclone and baghouse | Authority to Construct | 1998 | 0.1 lb/MMBtu (78 ppm @ 3% O ₂) | 181 ppmv @ 3% O ₂ (0.14 lb/MMBtu) | 0.02 lb/MMBtu (50 ppm @ 3% O ₂) | 23 ppm @ 3% O ₂ (0.041 lb/MMBtu) | 0.01 gr/scf @ 12% CO ₂ (0.022 lb/MMBtu) |

| Table D-6. Biomass-Fired Boiler | | | | | | | | | | |
|---------------------------------|---|--|---|------------------|------------------------------------|---|---|--|---|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 9 | Thermal Energy Development Corporation, Ltd.; Tracy, CA | 259 MMBtu/hr boiler (powers a 20.5 MW steam turbine electric generator) | Lime/ limestone injection, ammonia injection, ESP, SNCR | Permit | 7/31/2005 | 0.105 lb/MMBtu (82 ppm @ 3% O ₂) NH ₃ slip: 100 ppm @ 3% O ₂ | 0.21 lb/MMBtu (270 ppm @ 3% O ₂) | 0.049 lb/MMBtu (110 ppm @ 3% O ₂) | 0.024 lb/MMBtu (13 ppm @ 3% O ₂) | 0.034 lb/MMBtu (0.016 gr/scf @ 12% CO ₂) |
| 10 | AES Unit 2; Delano, CA | 400 MMBtu/hr bubbling fluidized bed boiler with (2) steam turbines producing 32 MW total | SNCR, limestone and sand injection, baghouse | Source test | 6/12 to 13/2007 | 0.08 lb/MMBtu; 63 ppmvd @ 3% O ₂ | 0.05 lb/MMBtu; 60 ppmvd @ 3% O ₂ | <0.0005 lb/MMBtu as methane | 0.0001 lb/MMBtu as SO ₂ ; 0.07 ppmvd @ 3% O ₂ | 0.002 gr/dscf @ 12% CO ₂ (total); (0.004 lb/MMBtu) |
| 11 | Rio Bravo; Fresno, CA | 352 MMBtu/hr circulating fluidized bed boiler with steam turbine producing 24.3 MW | SNCR, ESP | Source test | 11/11/2009 | 0.068 lb/MMBtu; 52 ppmvd @ 3% O ₂ NH ₃ : 11.7 ppm @ 3% O ₂ | 0.0004 lb/MMBtu; 0.47 ppmvd @ 3% O ₂ | 0.75 lb/hr as methane; 4.1 ppm @ 3% O ₂ | 0.0003 lb/MMBtu; 0.15 ppmvd @ 3% O ₂ | 0.002 gr/dscf @ 12% CO ₂ (filterable); 1.6 lb/hr (filterable); 7.7 lb/hr (condensable) |
| 12 | Pacific Industries; Lincoln, CA | 289.3 MMBtu/hr fixed grate boiler with steam turbine producing 20 MW | SNCR, multiclone, ESP | Source test | 2/9/2006 | 54 ppmvd @ 12% CO ₂ | N/A | N/A | N/A | 0.0005 gr/dscf @ 12% CO ₂ (total) |
| 13 | Madera Power; Madera, CA | 460 MMBtu/hr fluidized bed boiler with steam turbine producing 28.5 MW | SNCR | Source test | 8/25/2004 | 0.09 lb/MMBtu; 69 ppm @ 3% O ₂ | N/A | N/A | N/A | 0.006 gr/dscf @ 12% CO ₂ (total) |

| Table D-6. Biomass-Fired Boiler | | | | | | | | | | |
|---------------------------------|---|---|--|------------------|------------------------------------|---|---|------------------------|---|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 14 | Colmac Energy Inc.; Mecca, CA (Cabazon Reservation) | Boilers 1 and 2 – (2) 300 MMBtu/hr circulating fluidized bed boilers producing 47 MW total ⁸ | Thermal de-NOx system, cyclone / baghouse, limestone injection | Permit | 8/2/2000 | 30.0 lbs/hr per boiler; 94 ppmvd @ 3% O ₂ (3-hr avg.); 648 lbs/day per boiler; 0.30 lb/MMBtu (30-day rolling avg.) | 45.0 lbs/hr per boiler; 231 ppmvd @ 3% O ₂ (3-hr avg.) | 10.0 lbs/hr per boiler | 12.0 lbs/hr per boiler; 27 ppmvd @ 3% O ₂ (3-hr avg.); 70 tpy daily rolling avg. | 7.5 lbs/hr per boiler; 0.010 gr/dscf @ 12% CO ₂ ; 0.10 lb/MMBtu |

| Table D-7. Sewage Digester and Landfill Gas-Fired Fuel Cell | | | | | | | | | | |
|---|---|--|---|--------------------------------------|--|---------------------------|---------------------------|---------------------------|-----------------|-------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | ARB Distributed Generation Certification Regulation | DG unit subject to regulation and fueled by digester gas, landfill gas, or oil-field waste gas | Not specified | Regulation (effective date 9/7/2007) | On or after 1/1/2008 On or after 1/1/2013 | 0.5 lb/MWh 0.07 lb/MWh | 6.0 lb/MWh 0.10 lb/MWh | 1.0 lb/MWh 0.02 lb/MWh | | |
| 2 | El Estero Wastewater Treatment Plant; El Estero, CA | (2) Fuel Cell Energy Model DFC 300A fuel cells | Digester gas cleanup system to remove excess sulfur compounds, moisture, particulates, H ₂ S, halogenated compounds, and silohexanes (total sulfur content ≤12 ppmv) | Permit | | 0.07 lb/MWh; 0.018 lb/hr | 0.10 lb/MWh; 0.025 lb/hr | 0.02 lb/MWh; 0.005 lb/hr | 0.007 lb/hr | 0.026 lb/hr |

⁸ Boiler may be fired on natural gas and petroleum coke in addition to biomass (i.e., wood). Permit limits listed reflect biomass combustion.

| Table D-7. Sewage Digester and Landfill Gas-Fired Fuel Cell | | | | | | | | | | |
|---|---|--|----------------------|--|------------------------------------|--|--|--|---|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 3 | New York Power Authority/Red Hook Water Pollution Control Plant; Red Hook, NY | United Technologies Corp. PC25C phosphoric acid fuel cell producing 200 kW | | Source test | 5/19 to 6/19/2004 | 0.013 lb/MWh; 0.43 ppm @ 15% O ₂ | 0.029 lb/MWh; 1.64 ppm @ 15% O ₂ | 0.78 lb/MWh; 120 ppm @ 15% O ₂ | | |
| 4 | Orange County Sanitation District; Fountain Valley, CA | Fuel Cell Energy Model DFC300 fuel cell | | Permit (Manufacturer emission factor data) | 11/12/2008 | 0.01 lb/MWh; 0.0035 lb/hr; 0.08 lb/day | 0.1 lb/MWh; 0.035 lb/hr; 0.84 lb/day | 0.01 lb/MWh; 0.003 lb/hr; 0.07 lb/day | 0.0001 lb/MWh; 0.00003 lb/hr; 0 lb/day | 0.00002 lb/MWh; 0.000007 lb/hr; 0 lb/day |
| 5 | Palmdale Water Reclamation Plant; Palmdale, CA | Fuel Cell Energy Model DFC300 fuel cell producing 251 kW | | Source test | 1/19/2005 | 0.0017 lb/MWh; 0.05 ppm @ 15% O ₂ ; 0.1 ppm @ 3% O ₂ | 0.025 lb/MWh; 1.2 ppm @ 15% O ₂ ; 3.7 ppm @ 3% O ₂ | 0.016 lb/MWh (as CH ₄); 0.30 ppm @ 3% O ₂ (as hexane) | | |
| 6 | Penrose Landfill; Los Angeles, CA | International Fuel Cells PC25 phosphoric acid fuel cell producing 200 kW | | Source test | 2/17/1995 | 0.0053 lb/MWh; 0.12 ppmvd @ 15% O ₂ | 0.021 lb/MWh; 0.77 ppmvd @ 15% O ₂ | | <0.014 lb/MWh; <0.23 ppmvd @ 15% O ₂ | |

| Table D-8. Pumps and Compressor Seals | | | | | | | | | | |
|---------------------------------------|-----------------------------|-----------------|---|-----------------------|------------------------------------|---------------------|----|---|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | BAAQMD BACT Guideline 137.1 | Pumps | Double mechanical seals w/ barrier fluid and BAAQMD approved quarterly I&M Program | BACT (AIP) | 1/18/2006 | | | 500 ppm expressed as methane measured using EPA Reference Method 21 | | |
| | | | Double mechanical seals w/ barrier fluid; magnetically coupled pumps; canned pumps; magnetic fluid sealing technology or gas seal system vented to thermal oxidizer or other BAAQMD approved control device; all w/ BAAQMD approved quarterly I&M Program | BACT (tech. feasible) | | | | 100 ppm expressed as methane using EPA Reference Method 21 | | |

| Table D-8. Pumps and Compressor Seals | | | | | | | | | | |
|---------------------------------------|-----------------------------|-----------------|---|-----------------------|------------------------------------|---------------------|----|---|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 2 | BAAQMD BACT Guideline 48B.1 | Compressors | Double mechanical seals w/ barrier fluid and BAAQMD approved quarterly I&M Program | BACT (AIP) | 1/18/2006 | | | 500 ppm expressed as methane measured using EPA Reference Method 21 | | |
| | | | Double mechanical seals w/ barrier fluid; or gas seal system vented to thermal oxidizer or other BAAQMD approved control device; all w/ BAAQMD approved quarterly I&M Program | BACT (tech. feasible) | | | | 100 ppm expressed as methane using EPA Reference Method 21 | | |

| Table D-8. Pumps and Compressor Seals | | | | | | | | | | |
|---------------------------------------|--|---|----------------------|------------------------|------------------------------------|---------------------|----|--|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 3 | SJVAPCD Guideline 4.12.1 – Chemical Plants – Pumps and Compressor Seals ⁹ | Chemical plants pump and compressor seals | I&M Program | BACT (AIP) | 11/27/2006 | | | Leak defined as a reading of methane in excess of 500 ppmv above background when measure per EPA Method 21 and an Inspection and Maintenance Program pursuant to SJVAPCD Rule 4455 | | |
| 4 | BAAQMD Regulation 8 Rule 18 Equipment Leaks | Pumps and compressors | | District approved rule | Last amended 9/15/2004 | | | 500 ppm maximum leak rate using a hydrocarbon detector that meets the specifications and performance criteria of and has been calibrated using EPA Reference Method 21 | | |

⁹ Based on Lone Star Gas Liquids Processing, Inc., Bakersfield, CA.

| Table D-9. Valves, Flanges, and Other Types of Connectors | | | | | | | | | | |
|---|--|---------------------------------------|---|------------------------|------------------------------------|---------------------|----|---|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Pacific Ethanol; Madera, CA | Piping, valves and flanges | I&M program | Authority to Construct | 2005 | | | 100 ppmvd as methane maximum leak valves and flanges; 500 ppmvd as methane pumps and compressor seals | | |
| 2 | SJVAPCD Guideline 4.12.1 – Chemical Plants - Valves and Connectors | Chemical plants valves and connectors | I&M Program | BACT (AIP) | 11/26/2006 | | | Leak defined as a reading of methane in excess of 100 ppmv above background when measured per EPA Method 21 and Maintenance Program pursuant to SJVAPCD Rule 4455 | | |
| 3 | BAAQMD BACT Guideline 78.1 | Flanges | Graphitic gaskets and BAAQMD approved I&M Program | BACT (AIP) | 1/18/2006 | | | 100 ppm expressed as methane measured using EPA Reference Method 21 | | |

Table D-9. Valves, Flanges, and Other Types of Connectors

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|----------|---|------------------------|----------------------|------------------------|------------------------------------|---------------------|----|--|-----------------|------|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 4 | BAAQMD Regulation 8 Rule 18 Equipment Leaks | Valves and connections | | District approved rule | Last amended 9/15/2004 | | | 100 ppm maximum leak rate from valves and connections using a hydrocarbon detector that meets the specifications and performance criteria of and has been calibrated using EPA Reference Method 21 | | |

Table D-10. Wet Cooling Tower

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|----------|--|--|----------------------|---------------------------|------------------------------------|---------------------|----|-----|-----------------|---|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SJVAPCD Guideline 8.3.10 | Cooling Tower – Induced Draft, Evaporative Cooling | | BACT (tech. feasible) | 6/19/2000 | | | | | Cellular type drift eliminator |
| 2 | Los Esteros Critical Energy Facility Phase 2; San Jose, CA | Cooling tower, six-cell | | Final Commission Decision | October 2006 | | | | | High efficiency mist eliminator with maximum guaranteed drift rate of 0.0005% |
| 3 | Walnut Creek Energy, LLC; City of Industry, CA | Cooling tower, five-cell | | Authority to Construct | 10/27/2006 | | | | | Maximum 0.0005% drift loss |

| Table D-10. Wet Cooling Tower | | | | | | | | | | |
|-------------------------------|---|-----------------|----------------------|------------------|------------------------------------|---------------------|----|-----|-----------------|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 4 | Homeland Energy Solutions, LLC; Chickasaw County, IA | Cooling tower | | BACT-PSD | 7/21/2008 | | | | | Drift eliminator/demister with 0.0005% drift loss |
| 5 | Archer Daniels Midland (ADM) Corn Processing; Linn County, IA | Cooling tower | | BACT-PSD | 10/9/2007 | | | | | Drift eliminator with 0.0005% drift loss |

| Table D-11. Landfill Gas-Fired Flare | | | | | | | | | | |
|--------------------------------------|--|--|----------------------|-----------------------|------------------------------------|---|--|--|--|---------------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SJVAPCD Guideline 1.4.3 | Landfill gas-fired flare | Enclosed flare | BACT (tech. feasible) | 1/8/2001 | 0.05 lb/MMBtu (40 ppm @ 3% O ₂) | N/A | N/A | Wet scrubber w/ 98% control efficiency | Steam injection |
| 2 | SJVAPCD Guideline 1.4.3 | Landfill gas-fired flare | Enclosed flare | BACT (AIP) | 1/8/2001 | N/A | N/A | 98% control efficiency; 20 ppmv @ 3% O ₂ | N/A | N/A |
| 3 | SCAQMD Guidelines for Non-Major Facilities | Landfill gas-fired flare | | BACT | 2000 | 0.06 lb/MMBtu (50 ppm @ 3% O ₂) | N/A | N/A | N/A | Knockout vessel |
| 4 | Altamont Landfill; Livermore, CA | Landfill gas-fired flare | | Permit | 2005 | 0.06 lb/MMBtu (50 ppm @ 3% O ₂) | 0.30 lb/MMBtu (400 ppm @ 3% O ₂) | N/A | N/A | N/A |
| 5 | SCAQMD BACT Guidelines Part B, Section II (Waste Management of New Hampshire; Rochester, NH) | Flare, landfill gas from non-hazardous waste landfill (115.5 MMBtu/hr) | Enclosed flare | BACT | 4/18/2006 | 0.025 lb/MMBtu | 0.06 lb/MMBtu | 98% destruction efficiency or 20 ppm @ 3% O ₂ as hexane | 1.66 lb/hr; 0.014 lb/MMBtu | 2.32 lb/hr; 0.02 lb/MMBtu |

| Table D-11. Landfill Gas-Fired Flare | | | | | | | | | | |
|--------------------------------------|---|--|----------------------|------------------|------------------------------------|---|-----|---|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 6 | SCAQMD BACT Guidelines Part B, Section II (NEO Tajiguas Energy LLC; Goleta, CA) | Flare, landfill gas from non-hazardous waste landfill (63.68 MMBtu/hr) | Enclosed flare | BACT | 9/8/2004 | 35 ppmvd @ 3% O ₂ ; 0.048 lb/MMBtu | N/A | 1.25-second residence time and 1500 °F minimum temperature and 15 ppmvd @ 3% O ₂ as hexane; 0.038 lb/MMBtu | N/A | N/A |

| Table D-12. Manure Digester Gas-Fired Flare | | | | | | | | | | |
|---|--|---------------------------------|--|-----------------------|------------------------------------|--|--|--|---|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SJVAPCD Guideline 1.4.4 | Digester gas-fired flare | Ultra low NOx flare | BACT (tech. feasible) | 5/16/2006 | ≤0.03 lb/MMBtu (25 ppm @ 3% O ₂) | N/A | N/A | 1. Dry absorption of H ₂ S from the fuel gas 2. Wet absorption of H ₂ S from the fuel gas 3. Influent fuel H ₂ S reduction by addition of chemicals to the digester gas sludge 4. Water scrubbing of H ₂ S from the fuel gas | N/A |
| 2 | SJVAPCD Guideline 1.4.4 | Digester gas-fired flare | Enclosed flare | BACT (AIP) | 5/16/2006 | ≤0.06 lb/MMBtu (50 ppm @ 3% O ₂) | Operate per manufacturer specifications to minimize CO | ≤0.068 lb/MMBtu (161 ppm @ 3% O ₂) | LPG or natural gas-fired pilot | Smokeless combustion and LPG or natural gas-fired pilot |
| 3 | SJVAPCD Guideline 1.4.6 (Biorecycling Solutions) | Biogas-fired flare, limited use | | BACT (tech. feasible) | 1/20/1998 | 0.06 lb/MMBtu (50 ppm @ 3% O ₂) | N/A | 0.03 lb/MMBtu (71 ppm @ 3% O ₂) | N/A | N/A |
| 4 | SJVAPCD Guideline 2.2.3 | Cheese wastewater-fired flare | Enclosed flare, ultra low NOx burner, low NOx burner | BACT (tech. feasible) | 6/28/2004 | ≤0.03 lb/MMBtu (25 ppm @ 3% O ₂) | N/A | N/A | 99% H ₂ S removal (dry or wet scrubber) | Smokeless combustion and LPG or natural gas-fired pilot |

| Table D-13. Flare (Ethanol Production) | | | | | | | | | | |
|--|---|-----------------|----------------------|------------------|------------------------------------|---------------------------|---------------------------|-----------------------------------|----------------------|-----------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | ADM Corn Processing; Cedar Rapids, Iowa | Loadout flare | | Permit | 7/17/2008 | 0.15 lb/MMBtu | N/A | 95% control; 4.82 lb/hr; 12.2 tpy | 0.02 lb/hr; 0.09 tpy | 0.1gr/dscf |
| 2 | Center Ethanol Company, LLC; East St. Louis, IL | Loadout flare | | Permit | | 0.23 tons/month; 2.31 tpy | 0.39 tons/month; 3.87 tpy | 1.55 tons/month; 2.31 tpy | N/A | N/A |
| 3 | Pacific Ethanol; Madera, CA | Loadout flare | Low NOx burner | Permit | 7/8/2008 | 0.05 lb/MMBtu | 0.84 lb/MMBtu | 0.327 lb/MMBtu | 0.00285 lb/MMBtu | 0.0076 lb/MMBtu |
| 4 | Pacific Ethanol; Oregon | Loadout flare | | Permit | | 1.62 tpy | 2.71 tpy | 7.47 tpy | N/A | N/A |
| 5 | Phoenix Bio Industries; Goshen, CA | Loadout flare | Air assist | Permit | 9/20/2004 | 0.068 lb/MMBtu | 0.37 lb/MMBtu | 0.063 lb/MMBtu | 0.00285 lb/MMBtu | 0.008 lb/MMBtu |
| 6 | Pixley Ethanol; Pixley, CA | Loadout flare | Enclosed | Permit | 7/20/2005 | 0.068 lb/MMBtu | 0.37 lb/MMBtu | 0.063 lb/MMBtu | 0.00286 lb/MMBtu | 0.026 lb/MMBtu |

| Table D-14. Storage Tank (Fixed Roof) | | | | | | | | | | |
|---------------------------------------|---|---|--|------------------------|------------------------------------|---------------------|----|--|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | American Biodiesel; Stockton, CA | Methanol storage tank | Vapor recovery routed to distillation column and two-stage vapor condenser | Authority to Construct | 6/4/2007 | | | 99.5% control | | |
| 2 | SJVAPCD Guideline 7.3.1 - Petroleum and Petrochemical Production - Fixed Roof Organic Liquid Storage or Processing Tank, <5,000 bbl tank capacity ¹⁰ | Methanol storage tank | Waste gas incinerated in steam generator, heater treater, or other fired equipment and inspection and maintenance program: transfer of noncondensable vapors to gas pipeline; or equal | BACT (tech. feasible) | 10/1/2002 | | | 99% control | | |
| 3 | BAAQMD BACT Guideline 167.3.1 | ≥20,000 gallon storage tank – fixed roof, organic liquids | Thermal incinerator; or carbon adsorber; or refrigerated condenser; or BAAQMD approved equivalent | BACT (AIP) | 3/3/1995 | | | Vapor recovery system w/ an overall system efficiency ≥98% | | |
| 4 | NSPS 40 CFR Part 60 Subpart Kb | Methanol storage tank | Closed vent system and 95% VOC control efficiency | | | | | 95% control | | |

¹⁰ Based on District facility S-1339 heavy oil western stationary source.

| Table D-15. Storage Tank (Floating Roof) | | | | | | | | | | |
|--|---|--|--|--|------------------------------------|---------------------|----|--|-----------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | BAAQMD BACT Guideline 167.1.1 and Guideline 167.4.1 | Storage tank – external floating roof, organic liquids; storage tank – internal floating roof, organic liquids | <p>BAAQMD approved roof and seal design</p> <hr/> <p>Thermal incinerator; or carbon adsorber; or refrigerated condenser; or BAAQMD approved equivalent</p> | <p>BACT (AIP)</p> <hr/> <p>BACT (tech. feasible)</p> | 3/3/1995 | | | <p>BAAQMD approved roof w/ liquid mounted primary seal and zero gap secondary seal, all meeting design criteria of Reg. 8, Rule 5; no ungasketed roof penetrations, no slotted pipe guide pole unless equipped w/ float and wiper seals, and no adjustable roof legs unless fitted w/ vapor seal boots or equivalent</p> <hr/> <p>Vapor recovery system w/ an overall system efficiency ≥98%</p> | | |

| Table D-15. Storage Tank (Floating Roof) | | | | | | | | | | |
|--|---|---|--|------------------------|------------------------------------|---------------------|----|-------------|-----------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 2 | Calgren Renewable Fuels LLC; Pixley, CA | Ethanol tank (from 67,700 to 1,000,000 gallons) | Tank equipped with double seals, one mounted on top of the other (meeting SJVAPCD Rule 4623) | Authority to Construct | 8/24/2005 | | | 95% control | | |

| Table D-16. Dryer | | | | | | | | | | |
|-------------------|---|--|--|-----------------------|------------------------------------|--|-----------------------------|--|------------------------------|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | SJVAPCD Guideline 4.12.6 A | Distillers Dried Grains with Solubles (DDGS) Dryer | Low NOx burners, cyclone, thermal or catalytic incinerator | BACT (AIP) | 5/25/2004 | 33 ppmv @ 3% O ₂ ; 0.04 lb/MMBtu | N/A | VOC capture and control with thermal or catalytic incineration (98% control) or equivalent | Natural gas fuel | High efficiency (1D-3D) cyclones and thermal incinerator in series (98.5% control) or equivalent |
| 2 | SJVAPCD Guideline 4.12.6 A | Distillers Dried Grains with Solubles (DDGS) Dryer | Ultra low NOx burners, wet scrubber | BACT (tech. feasible) | 5/25/2004 | 15 ppmv @ 3% O ₂ ; 0.018 lb/MMBtu | N/A | N/A | Wet scrubber (95% control) | N/A |
| 3 | Golden Grain Energy; Cerro Gordo County, IA | Distillers Dried Grains with Solubles (DDGS) Dryer (42 MMBtu/hr) | Low NOx burners, FGR, thermal oxidizer | BACT-PSD | 4/19/2006 | 8.36 lb/hr; 0.04 lb/MMBtu (30-day avg.) | 25.5 lb/hr; 0.61 lb/MMBtu | 98% control; 2.75 lb/hr (0.065 lb/MMBtu) | N/A | 4.5 lb/hr; 0.03 lb/MMBtu (3-hr avg.) |
| 4 | Abengoa Bioenergy of Illinois, LLC; Madison, IL | Indirect Feed Dryer (76.7 MMBtu/hr) | Integral cyclone and burner/kiln | Permit | 7/13/2007 | 6.52 lb/hr (0.085 lb/MMBtu) | 7.97 lb/hr (0.104 lb/MMBtu) | 1.96 lb/hr (0.026 lb/MMBtu) | 0.04 lb/hr (0.0005 lb/MMBtu) | 3.71 lb/hr (0.048 lb/MMBtu) |

| Table D-16. Dryer | | | | | | | | | | |
|-------------------|----------------------------------|---|--|------------------|------------------------------------|---|--|---|---|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 5 | Bluefire Ethanol; Lancaster, CA | Biomass dryer (shared stack with CFB biomass boiler ¹¹) | Baghouse, SOx scrubber with limestone, and SNCR with aqueous NH ₃ injection | Permit | 12/16/2008 | 144 lb/day; 0.075 lb/MMBtu (Combined boiler and dryer daily emission limit; lb/MMBtu limit from district engineering evaluation) | 134.4 lb/day; 0.07 lb/MMBtu (Combined boiler and dryer daily emission limit; lb/MMBtu limit from district engineering evaluation) | 103.5 lb/day; 0.013 lb/MMBtu (Combined boiler and dryer daily emission limit; lb/MMBtu limit from district engineering evaluation) | 132.5 lb/day; 0.069 lb/MMBtu (Combined boiler and dryer daily emission limit; lb/MMBtu limit from district engineering evaluation) | 42.3 lb/day; 0.022 lb/MMBtu (Combined boiler and dryer daily emission limit; lb/MMBtu limit from district engineering evaluation) |
| 6 | American Biodiesel; Stockton, CA | Steam-heated feedstock Dryer (completely enclosed) | Vapor recovery system | Permit | 6/4/2007 | | | 99.5 % control | | |

¹¹ Dual fuel firing occurs at startup using 25 MMBtu/hr natural gas-fired burner for overbed air and 15 MMBtu/hr natural gas-fired burner for underbed air.

| Table D-17. Pyrolyzer | | | | | | | | | | |
|-----------------------|---|--|---|---|------------------------------------|---|--|--|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | International Environmental Solutions Corp.; Romoland, CA | Non-hazardous feedstocks pyrolysis system, including pyrolytic thermal converter (retort), indirectly heated with (4) Eclipse Therm Jet low NOx burners, Model TJ150, natural gas-fired, 1.5 MMBtu/hr each, with a combustion air blower and hydraulically driven variable speed helical screw | Low-NOx burners, pyrolytic converter vented to control system consisting of: multiclone, thermal oxidizer, waste heat boilers, activated carbon injection system, baghouse, wet scrubber, exhaust stack with in-stack mounted carbon filter | Permit to Construct and Operate Experimental Research Project ¹² Note: This was an experimental research demonstration project and is no longer operating, nor is the permit valid anymore. | 3/7/2006 | Pyrolysis gas burner stack: 6 lbs/day Scrubber stack: 34 lbs/day (NH ₃ : 2.5 lbs/day) | Pyrolysis gas burner stack: 5 lbs/day Scrubber stack: 9 lbs/day | Pyrolysis gas burner stack: 1 lb/day Scrubber stack: 11 lbs/day | Pyrolysis gas burner stack: 0.1 lb/day Scrubber stack: 1 lb/day | Pyrolysis gas burner stack: 1 lb/day Scrubber stack: 1 lb/day |

| Table D-18. Liquid Fuel Loading Operations | | | | | | | | | | |
|--|---|-----------------------|---|------------------|------------------------------------|---------------------|----|----------------------------|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Abengoa Bioenergy of Illinois, LLC; Madison, IL | Ethanol Loadout Racks | | Permit | 7/13/2007 | | | 1.45 tons/month; 14.45 tpy | | |
| 2 | Bluefire Ethanol; Lancaster, CA | Ethanol Loadout | Vapor recovery and control system, beer vent scrubber | Permit | 12/16/2008 | | | 50 ppmv; 2.8 lb/day | | |

¹² Permit conditions were crafted to limit operating hours and emissions to just below the levels that would trigger federal requirements for small municipal solid waste combustors. According to SCAQMD staff, is it likely that more efficient air pollution control would have been required if the company requested either more operating time and/or higher throughput.

| Table D-18. Liquid Fuel Loading Operations | | | | | | | | | | |
|--|---|-------------------|----------------------------|------------------|------------------------------------|---------------------|----|--|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 3 | Lomita Rail Terminal, LLC; Carson, CA | Ethanol Unloading | Carbon adsorber | Permit | 12/2/2003 | | | Leak defined as a reading of methane greater than 500 ppm but less than 1000 ppm above background when measured per EPA Method 21. Leak greater than 1000 ppm above background shall be repaired according to SCAQMD Rule 1173 | | |
| 4 | Verenium Biofuels; Jennings, Jefferson Davis Parish, LA | Ethanol loadout | Carbon adsorption canister | Permit | 5/13/2008 | | | 98% control | | |

| Table D-18. Liquid Fuel Loading Operations | | | | | | | | | | |
|--|---|--|---------------------------------------|------------------|------------------------------------|---------------------|----|--|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 5 | West Colton Rail Terminal LLC; Rialto, CA | Railcar unloading/truck loading, ethanol | Carbon adsorber, vapor balance system | Permit | 11/10/2009 | | | 0.08 lbs/1000 gallons loaded (SCAQMD Rule 462 – Organic Liquid Loading) and leak defined as a reading of methane greater than 500 ppm but less than 1000 ppm above background when measured per EPA Method 21. Leak greater than 1000 ppm above background shall be repaired according to SCAQMD Rule 1173 | | |

| Table D-19. Compressed Gas Dispensing Operations | | | | | | | | | | |
|--|---|--|--|------------------|------------------------------------|---|----|-----|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | Los Angeles County Sanitation District, aka Puente Hills Landfill; Whittier, CA | Landfill gas treating and dispensing system (250 scfm collected and treated to produce CNG for pick-up trucks) | All vent gases and excess processed gas shall be directed to combustion or processing facility that can adequately process the gas and has been issued a valid District permit | Permit | 2/12/1997 | No direct emissions – operation of equipment shall not result in release of any gas or condensate into the atmosphere | | | | |
| 2 | Sonoma County Central Landfill; Petaluma, CA | Landfill gas compression plant, pilot scale (100 scfm collected and treated to produce CNG for vehicles) | Closed loop system w/ no vents or exhaust stacks; all waste gas transferred to treatment systems or flared | Permit | 4/18/2008 | No direct emissions – closed loop system | | | | |

| Table D-20. Liquid Fuel Transfer and Dispensing Operations | | | | | | | | | | |
|--|--|--|---|------------------|------------------------------------|---------------------|----|-----|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SCAQMD Rule 461 Gasoline Transfer and Dispensing | Fuel ¹³ transfer into stationary storage tanks and mobile fuelers | Phase I vapor recovery system ¹⁴ | Rule | 3/7/2008 | | | | | |

¹³ Applies to biofuel blends that meet the definition of “gasoline” as defined in Rule 461.

¹⁴ Rule 461 exempts the dispensing of E-85 into a mobile fueller of vehicle fuel tank from Phase II vapor recovery requirements until April 1, 2012.

| Table D-21. Sewage Digester and Landfill Gas-Fired Microturbine | | | | | | | | | | |
|---|---|--|----------------------|--|------------------------------------|--|--|--|---|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | Capstone Turbine Corporation; Chatsworth, CA | Capstone CR65 digester gas-fueled microturbine | | Source test (for ARB DG Certification Program) | 6/8/2007 | 0.15 lb/MWh; 8.73 ppmvd @ 3% O ₂ ; 3 ppmvd @ 15% O ₂ | 4.52 lb/MWh; 385.92 ppmvd @ 3% O ₂ ; 127 ppmvd @ 15% O ₂ | 0.23 lb/MWh; 42.06 ppmvd @ 3% O ₂ as CH ₄ (total non-methane, non-ethane organic compounds); 14 ppmvd @ 15% O ₂ | 8.64 ppmvd @ 3% O ₂ ; 3 ppmvd @ 15% O ₂ | |
| 2 | Capstone Turbine Corporation; Chatsworth, CA | Capstone CR65 landfill gas-fueled microturbine | | Source test (for ARB DG Certification Program) | 8/8/2007 | 0.10 lb/MWh; 4.56 ppmvd @ 3% O ₂ ; 2 ppmvd @ 15% O ₂ | 0.61 lb/MWh; 31.48 ppmvd @ 3% O ₂ ; 10 ppmvd @ 15% O ₂ | 0.13 lb/MWh; 18.46 ppmvd @ 3% O ₂ as CH ₄ (total non-methane, non-ethane organic compounds); 6 ppmvd @ 15% O ₂ | 32.11 ppmvd @ 3% O ₂ ; 11 ppmvd @ 15% O ₂ | |
| 3 | Ingersoll Rand Energy Systems; Portsmouth, NH | Ingersoll Rand 250 kW 250ST digester gas-fueled microturbine | | Source test (for ARB DG Certification Program) | 1/16/2008 | 0.114 lb/MWh; 2.2 ppmvd @ 15% O ₂ | 0.029 lb/MWh; 0.9 ppmvd @ 15% O ₂ | 0.13 lb/MWh; 1.3 ppmvd @ 15% O ₂ (as hexane) | 0.018 lb/hr | |
| 4 | Ingersoll Rand Energy Systems; Portsmouth, NH | Ingersoll Rand 250 kW 250SW landfill gas-fueled microturbine | | Source test (for ARB DG Certification Program) | 1/9/2008 | 0.36 lb/MWh; 6.5 ppmvd @ 15% O ₂ | 0.041 lb/MWh; 1.2 ppmvd @ 15% O ₂ | 0.10 lb/MWh; 0.92 ppmvd @ 15% O ₂ (as hexane) | 0.017 lb/hr | |

| Table D-22. Landfill Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|---|--|--|---|------------------|------------------------------------|---|--|--|-----------------|-------------------------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SCAQMD Rule 1110.2 Emissions from Gaseous- and Liquid-Fueled Engines | Stationary and portable engines >50 bhp, landfill and digester gas-fired | | Rule | 2/1/2008 | <500 bhp: 45 x ECF ¹⁵ ppmvd @ 15% O ₂ ≥500 bhp: 36 x ECF ppmvd @ 15% O ₂ On and after 7/1/2012: 11 ppmvd @ 15% O ₂ | 2,000 ppmvd @ 15% O ₂ On and after 7/1/2012: 250 ppmvd @ 15% O ₂ | 40 ppmvd @ 15% O ₂ On and after 7/1/2012: 30 ppmvd @ 15% O ₂ | N/A | N/A |
| 2 | 8309 Tujunga Ave. Corp. (Austin Rd. Landfill); Stockton, CA | 1,100 hp landfill gas-fired IC engine | | Source test | 12/13/2006 | 0.3 g/bhp-hr; 20 ppmv @ 15% O ₂ | 3.0 g/bhp-hr; 291 ppmv @ 15% O ₂ | 0.2 g/bhp-hr; 38 ppmv @ 15% O ₂ | Non-detected | 0.01 g/bhp-hr; 0.001 gr/dscf |
| 3 | ARB DG Guidance ¹⁶ | Waste gas-fired reciprocating engine used in electrical generation (that are required to obtain a district permit) | Lean-burn technology | BACT | 2002 | 0.6 g/bhp-hr; 50 ppmvd @ 15% O ₂ ; 1.9 lb/MWh | 2.5 g/bhp-hr; 300 ppmvd @ 15% O ₂ ; 7.8 lb/MWh | 0.6 g/bhp-hr; 130 ppmvd @ 15% O ₂ ; 1.9 lb/MWh | N/A | N/A |
| 4 | Apollo Energy III (Bowerman Landfill); Irvine, CA | 1,468 bhp landfill gas IC engine, producing 1.06 MW | Lean burn technology, turbocharged, aftercooled | Permit | | 0.5 g/bhp-hr | 0.3 g/bhp-hr | 0.2 g/bhp-hr (NMHC) | N/A | N/A |
| 5 | Apollo Energy III (Bowerman Landfill); Irvine, CA | 1,468 bhp landfill gas IC engine, producing 1.06 MW | Lean burn technology, turbocharged, aftercooled | Source test | 7/05 to 06/2007 | 0.4 g/bhp-hr; 32 ppm @ 15% O ₂ | 0.2 g/bhp-hr; 19 ppm @ 15% O ₂ | 0.01 g/bhp-hr (CH ₄) TGNMO | N/A | 0.004 gr/dscf @ 12% CO ₂ |

¹⁵ ECF is the efficiency correction factor. ECF = 1.0 unless the engine operator has measured the engine's net specific energy consumption, in compliance with ASME Performance Test Code PTC 17-1973, at the average load of the engine (see rule for details).

¹⁶ Emission levels based on permit and source test data from the following facilities: County of Sacramento (Kiefer Landfill), Energy Developments (Azusa Landfill), Minnesota Methane (Tajiguas Landfill), Riverside County Waste Management (Badlands), Minnesota Methane (Lopez Landfill), Minnesota Methane (Corona), Ogden Power Pacific (Stockton), Orange County Sanitation District (Huntington Beach).

Table D-22. Landfill Gas-Fired Reciprocating Internal Combustion Engine

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|-----------|---|--|------------------------------------|-----------------------|------------------------------------|--|---|--|----------------------|---------------|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 6 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Permit | | 0.4 g/bhp-hr OR 30.0 ppmv @ 15% O ₂ (both 3-hr avg) | 2.6 g/bhp-hr OR 366 ppmv @ 15% O ₂ (both 3-hr avg) | 0.1 g/bhp-hr | 0.3 g/bhp-hr | 0.1 g/bhp-hr |
| 7 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 1 | 11/10/2005 | 0.3 g/bhp-hr; 24 ppm @ 15% O ₂ | 1.9 g/bhp-hr; 253 ppm @ 15% O ₂ | Failed | Fuel: 0.6 gr/100 scf | 0.06 g/bhp-hr |
| 8 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 1 | 10/25/2006 | 0.3 g/bhp-hr; 2 ppm @ 15% O ₂ | 2.2 g/bhp-hr; 241 ppm @ 15% O ₂ | N/A | Fuel: 29 ppmv | Failed |
| 9 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 1 | 1/31/2007 | N/A | N/A | N/A | Fuel: 22 ppmv | 0.04 g/bhp-hr |
| 10 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 1 | 3/28/2007 | 0.3 g/bhp-hr; 23 ppm @ 15% O ₂ | 2.0 g/bhp-hr; 241 ppm @ 15% O ₂ | 0.06 g/bhp-hr; 2.3 ppmv @ 15% O ₂ as hexane | Fuel: 22 ppmv | 0.04 g/bhp-hr |
| 11 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 2 | 11/09/2005 | 0.3 g/bhp-hr; 26 ppm @ 15% O ₂ | 2.0 g/bhp-hr; 224 ppm @ 15% O ₂ | Failed | Fuel: 0.2 gr/100 scf | 0.10 g/bhp-hr |
| 12 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 2 | 10/26/2006 | 0.4 g/bhp-hr; 24 ppm @ 15% O ₂ | 1.7 g/bhp-hr; 233 ppm @ 15% O ₂ | N/A | Fuel: 29 ppmv | 0.07 g/bhp-hr |
| 13 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 2 | 3/27/2007 | 0.3 g/bhp-hr; 25 ppm @ 15% O ₂ | 1.9 g/bhp-hr; 245 ppm @ 15% O ₂ | 0.05 g/bhp-hr; 2.2 ppmv @ 15% O ₂ as hexane | Fuel: 22 ppmv | 0.04 g/bhp-hr |
| 14 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 3 | 11/08/2005 | 0.3 g/bhp-hr; 21 ppm @ 15% O ₂ | 1.8 g/bhp-hr; 220 ppm @ 15% O ₂ | 0.08 g/bhp-hr as CH ₄ | Fuel: 0.3 gr/100 scf | 0.05 g/bhp-hr |
| 15 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 3 | 1/30/2007 | 0.3 g/bhp-hr; 23 ppm @ 15% O ₂ | 1.7 g/bhp-hr; 199 ppm @ 15% O ₂ | 0.1 g/bhp-hr as CH ₄ | Fuel: 22 ppmv | 0.05 g/bhp-hr |

| Table D-22. Landfill Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|---|--|---|--|------------------------|------------------------------------|---|--|--|---|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 16 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 4 | 5/11/2006 | 0.3 g/bhp-hr; 21 ppm @ 15% O ₂ | 1.6 g/bhp-hr; 209 ppm @ 15% O ₂ | 0.05 g/bhp-hr as hexane | Fuel: 34 ppmv | 0.08 g/bhp-hr |
| 17 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 4 | 4/04/2007 | 0.3 g/bhp-hr; 26 ppm @ 15% O ₂ | 2.4 g/bhp-hr; 304 ppm @ 15% O ₂ | 0.10 g/bhp-hr; 4.0 ppmv as hexane | Fuel: 22 ppmv | 0.09 g/bhp-hr |
| 18 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 5 | 5/12/2006 | 0.3 g/bhp-hr; 22 ppm @ 15% O ₂ | 1.7 g/bhp-hr; 205 ppm @ 15% O ₂ | 0.06 g/bhp-hr as hexane | Fuel: 34 ppmv | 0.08 g/bhp-hr; 0.009 gr/dscf |
| 19 | Kiefer Landfill; Sacramento, CA – 5 units | 4,230 bhp landfill gas-fired IC engine, producing 3.05 MW each | Lean burn technology, turbocharged | Source test Unit 5 | 3/29 to 30/2007 | 0.4 g/bhp-hr; 27 ppm @ 15% O ₂ | 2.0 g/bhp-hr; 253 ppm @ 15% O ₂ | 0.07 g/bhp-hr; 2.9 ppmv as hexane | Fuel: 22 ppmv | 0.08 g/bhp-hr; 0.009 gr/dscf |
| 20 | MM San Bernardino Energy, LLC (Milliken Landfill); Ontario, CA | 1850 bhp (14.7 MMBtu/hr) Deutz Model TBG620V16K landfill gas-fired IC engine | Engine design, air/fuel ratio controller, turbocharger, intercooler | BACT (NOx, CO, VOC) | 2/20/2003 | 0.6 g/bhp-hr | 2.5 g/bhp-hr | 0.8 g/bhp-hr | 0.10 lb/hr; 0.02 g/bhp-hr; 0.007 lb/MMBtu | 0.20 lb/hr; 0.05 g/bhp-hr; 0.014 lb/MMBtu |
| 21 | Minnesota Methane Tajiguas Corp.; Goleta, CA | 4314 bhp Caterpillar Model 3616 landfill gas-fired engine driving a 3 MW generator with exhaust routed to afterburner/standby flare | Lean-burn technology w/ spark ignition controls, air/fuel ratio controls, intake air turbocharger and intercooler, fuel pretreatment to remove gas condensate and filter particles | BACT | 1/9/1998 | 0.59 g/bhp-hr | N/A | 0.24 g/bhp-hr | N/A | 0.34 g/bhp-hr |
| 22 | Puente Hills Landfill; Whittier, CA – 3 units | 4,261 bhp landfill gas-fired engine, with natural gas as secondary fuel | Lean burn technology, turbocharged, aftercooled, producing 3 MW | Permit | | 0.6 g/bhp-hr | 2.5 g/bhp-hr | ROC: 0.8 g/bhp-hr; NMHC: 20 ppmv @ 3% O ₂ OR 98% reduction | N/A | N/A |

| Table D-22. Landfill Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|---|--|--|---|---------------------------|------------------------------------|---|--|---|-----------------|--------------------------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 23 | Puente Hills Landfill, Whittier, CA Unit 1 | 4,261 bhp landfill gas-fired IC engine, with natural gas as secondary fuel | Lean burn technology, turbocharged, aftercooled, producing 3 MW | Source test | 7/11 to 14/2006 | 0.4 g/bhp-hr | 1.7 g/bhp-hr | 0.2 g/bhp-hr; 18.4 ppm @ 3% O ₂ (as hexane) | N/A | N/A |
| 24 | Ridgewood Olinda Management, LLC; Brea, CA – 3 units | 2,650 bhp landfill gas-fired IC engine, no auxiliary fuel, producing 1.875 MW each | Siloxane scrubber | Permit | 11/17/2004 | 36 ppm @ 15% O ₂ ; 0.7 g/bhp-hr | 2000 ppm @ 15% O ₂ ; 22.7 g/bhp-hr | 250 ppm as CH ₄ @ 15% O ₂ | N/A | N/A |
| 25 | Ridgewood Olinda Management, LLC; Brea, CA Unit 1 | 2,650 bhp landfill gas-fired IC engine, no auxiliary fuel, producing 1.875 MW each | Siloxane scrubber | Source test ¹⁷ | 6/13/2007 | 31 ppm @ 15% O ₂ ; 0.5 g/bhp-hr | 2 ppm @ 15% O ₂ ; 0.0 g/bhp-hr | 4 ppm @ 15% O ₂ as CH ₄ , TGNMO; 0.02 g/bhp-hr | 1.85 ppm | 0.0006 gr/dscf @ 12% CO ₂ |
| 26 | Simi Valley Landfill; Simi Valley, CA – 2 units | 1,877 bhp landfill gas-fired IC engine | Lean burn technology, turbocharged, aftercooled | Permit | | 35 ppmvd @ 15% O ₂ OR 0.6 g/bhp-hr | 280 ppmvd @ 15% O ₂ ; 3.2 g/bhp-hr | 28 ppmvd @ 15% O ₂ ; 1.0 g/bhp-hr | 0.02 lb/MMBtu | N/A |
| 27 | Waste Management; Livermore, CA | (2) 1,877 bhp Deutz IC engines fueled by landfill gas, LNG, or LNG Plant waste gas (Units S-23 and S-24) | | Permit | | 0.6 g/bhp-Hr OR 36 ppmvd @ 15% O ₂ | 2.1 g/bhp-hr OR 207 ppmvd @ 15% O ₂ | 98% destruction efficiency by weight OR <120 ppmv @ 3% O ₂ ¹⁸ | N/A | N/A |
| 28 | BAAQMD Guideline 96.2.2 | IC engine – landfill gas fired <250 bhp output | Modified rich burn technology | BACT (AIP) | 6/15/2006 | 2.5 g/bhp-hr | 10.0 g/bhp-hr | 1.5 g/bhp-hr | 0.5 g/bhp-hr | N/A |

¹⁷ There are two test result tables for this test. The numbers differ between the tables. The data shown here came from the table with the higher reported emissions.

¹⁸ Requirement from District Rule 8-34-301.4 (last amended June 15, 2005).

Table D-22. Landfill Gas-Fired Reciprocating Internal Combustion Engine

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|-----------|-------------------------|---|----------------------|------------------|------------------------------------|---------------------|---|---|-----------------|------|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 29 | BAAQMD Guideline 96.2.2 | IC engine – landfill gas fired >250 bhp output, low-NOx engine bias | Lean burn technology | BACT (AIP) | 3/5/2009 | 0.5 g/bhp-hr | Initial standard: 2.5 g/bhp-hr Not to exceed standard: 3.9 g/bhp-hr CO emissions based on overhaul schedule | 120 ppm @ 3% O ₂ (0.16 g/bhp-hr) | N/A | N/A |
| 30 | BAAQMD Guideline 96.2.2 | IC engine – landfill gas fired >250 bhp output, low-CO engine bias | Lean burn technology | BACT (AIP) | 3/5/2009 | 0.6 g/bhp-hr | Initial standard: 2.1 g/bhp-hr Not to exceed standard: 3.6 g/bhp-hr CO emissions based on overhaul schedule | 120 ppm @ 3% O ₂ (0.16 g/bhp-hr) | N/A | N/A |

| Table D-23. Sewage Digester Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|--|--|--|--|------------------|------------------------------------|---|--|---|-----------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NO _x | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | SCAQMD Rule 1110.2 Emissions from Gaseous- and Liquid-Fueled Engines | Stationary and portable engines >50 bhp, landfill and digester gas-fired | | Rule | 2/1/2008 | <500 bhp: 45 x ECF ¹⁹ ppmvd @ 15% O ₂ ≥500 bhp: 36 x ECF ppmvd @ 15% O ₂ On and after 7/1/2012: 11 ppmvd @ 15% O ₂ | 2,000 ppmvd @ 15% O ₂ On and after 7/1/2012: 250 ppmvd @ 15% O ₂ | 250 x ECF ppmvd @ 15% O ₂ On and after 7/1/2012: 30 ppmvd @ 15% O ₂ | N/A | N/A |
| 2 | ARB DG Guidance ²⁰ | Waste gas-fired reciprocating engine used in electrical generation (that are required to obtain a district permit) | Lean-burn technology, pre-stratified charge system | BACT | 2002 | 0.6 g/bhp-hr; 50 ppmvd @ 15% O ₂ ; 1.9 lb/MWh | 2.5 g/bhp-hr; 300 ppmvd @ 15% O ₂ ; 7.8 lb/MWh | 0.6 g/bhp-hr; 130 ppmvd @ 15% O ₂ ; 1.9 lb/MWh | N/A | N/A |
| 3 | Hill Canyon Wastewater Treatment Plant; Camarillo, CA – 2 units | 396 bhp sewage digester gas-fired IC engines, producing 250 kW each | Catalytic carbon control systems for removing H ₂ S and ROCs, lean burn technology, turbocharged and aftercooled, low NO _x combustion chambers | Permit | | 0.6 g/bhp-hr OR 35 ppmvd @ 15% O ₂ | 13.6 g/bhp-hr; 1200 ppmvd @ 15% O ₂ | 1.0 g/bhp-hr; 28 ppmvd @ 15% O ₂ | Fuel: 20 ppmvd | N/A |

¹⁹ ECF is the efficiency correction factor. ECF = 1.0 unless the engine operator has measured the engine's net specific energy consumption, in compliance with ASME Performance Test Code PTC 17-1973, at the average load of the engine (see rule for details).

²⁰ Emission levels based on permit and source test data from the following facilities: City of Stockton, Hemet/San Jacinto Regional Water Reclamation Facility, South East Regional Reclamation Authority (Dana Point).

| Table D-23. Sewage Digester Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|--|---|---|--|---|------------------------------------|---|--|---|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 4 | San Bernardino City Municipal Water Dept.; San Bernardino, CA – 2 units | 999 bhp sewage digester gas (w/ natural gas augmentation)-fired IC engine | Lean burn technology, turbocharged and aftercooled | Permit | | 0.6 g/bhp-hr; 36 ppmvd @ 15% O ₂ | 2.5 g/bhp-hr; 2000 ppmvd @ 15% O ₂ | 0.3 g/bhp-hr; 250 ppmvd @ 15% O ₂ | 500 ppmv | 0.1 gr/dscf @ 12% CO ₂ |
| 5 | San Bernardino City Municipal Water Dept.; San Bernardino, CA Unit 1 | 999 bhp sewage digester gas (w/ natural gas augmentation)-fired IC engine | Lean burn technology, turbocharged and aftercooled | Source test (85% load, 100% digester gas) | 11/3 to 4/2005 | 0.2 g/bhp-hr; 13 ppmvd @ 15% O ₂ (1 run) | 1.3 g/bhp-hr; 115 ppmvd @ 15% O ₂ (1 run) | 0.1 g/bhp-hr; 18 ppmvd @ 15% O ₂ TGNMNEO (2-run avg) | N/A | 0.002 gr/dscf @ 12% CO ₂ (1 run) |
| 6 | San Bernardino City Municipal Water Dept.; San Bernardino, CA Unit 2 | 999 bhp sewage digester gas (w/ natural gas augmentation)-fired IC engine | Lean burn technology, turbocharged and aftercooled | Source test (85% load, 100% digester gas) | 11/1 to 2/2005 | 0.2 g/bhp-hr; 11 ppmvd @ 15% O ₂ (1 run) | 1.4 g/bhp-hr; 121 ppmvd @ 15% O ₂ (1 run) | 0.1 g/bhp-hr; 13 ppmvd @ 15% O ₂ TGNMNEO (2-run avg) | N/A | 0.001 gr/dscf @ 12% CO ₂ (1 run) |
| 7 | San Francisco South East Treatment Plant; San Francisco, CA | 21 MMBtu/hr sewage digester gas +/- natural gas-fired IC engine | | Permit | | 0.5 g/bhp-hr | 2.1 g/bhp-hr | 0.6 g/bhp-hr (POC) | 0.3 g/bhp-hr (equivalent to fuel H ₂ S content of 300 ppmv) | N/A |
| 8 | Stockton RWCF; Stockton, CA | 1,408 bhp sewage digester/natural gas-fired IC engine | Lean burn technology, with precombustion chamber and siloxane scrubber | Source test (digester gas) | 10/11 to 12/2006 | 0.4 g/bhp-hr; 22 ppm @ 15% O ₂ | 2.6 g/bhp-hr; 264 ppm @ 15% O ₂ | 0.1 g/bhp-hr TNMHC | 0.1 g/bhp-hr | <0.1 g/bhp-hr; <0.01 gr/dscf @ 12% CO ₂ |

Table D-23. Sewage Digester Gas-Fired Reciprocating Internal Combustion Engine

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|----------|-------------------------|--|--|-----------------------|------------------------------------|---------------------|--|--------------|-----------------|------|
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 9 | BAAQMD Guideline 96.5.2 | IC engine – digester gas fired, >50 bhp output | Lean burn technology, digester gas pretreatment to remove H ₂ S | BACT (AIP) | 5/14/2009 | 1.25 g/bhp-hr | Initial standard: 2.65 g/bhp-hr Not to exceed standard: 3.77 g/bhp-hr CO emissions based / minimum overhaul schedule | 1.0 g/bhp-hr | 0.3 g/bhp-hr | N/A |
| 10 | BAAQMD Guideline 96.5.2 | IC engine – digester gas fired, >50 bhp output | Digester gas pretreatment w/ >80% H ₂ S removal | BACT (tech. feasible) | 5/14/2009 | 1.0 g/bhp-hr | 2.1 g/bhp-hr | 0.6 g/bhp-hr | N/A | N/A |

| Table D-24. Manure Digester and Co-Digester Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|--|--|---|-------------------------|------------------------|------------------------------------|--|--|---|------------------------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | SCAQMD Rule 1110.2 Emissions from Gaseous- and Liquid-Fueled Engines | Stationary and portable engines >50 bhp, landfill and digester gas-fired | | Rule | 2/1/2008 | <500 bhp: 45 x ECF ²¹ ppmvd @ 15% O ₂ | 2,000 ppmvd @ 15% O ₂ | 250 x ECF ppmvd @ 15% O ₂ | N/A | N/A |
| | | | | | | ≥500 bhp: 36 x ECF ppmvd @ 15% O ₂ | | | | |
| | | | | | | On and after 7/1/2012: 11 ppmvd @ 15% O ₂ | On and after 7/1/2012: 250 ppmvd @ 15% O ₂ | On and after 7/1/2012: 30 ppmvd @ 15% O ₂ | | |
| 2 | Fiscalini Farms & Fiscalini Dairy; Modesto, CA | 1,057 bhp Guascor Model SFGLD-560 dairy digester gas-fired lean-burn IC engine driving 750 kW generator | Oxidation catalyst, SCR | Authority to Construct | 12/17/2008 | 0.15 g/bhp-hr (11.0 ppmvd @ 15% O ₂) and shall not exceed 0.60 g/bhp-hr (44 ppmvd @ 15% O ₂) ²² NH ₃ limit: 10 ppmvd @ 15% O ₂ | 1.75 g/bhp-hr (210 ppmvd @ 15% O ₂) | 0.13 g/bhp-hr (28 ppmvd @ 15% O ₂) | Fuel sulfur content ≤50 ppmv | 0.036 g/bhp-hr |

²¹ ECF is the efficiency correction factor. ECF = 1.0 unless the engine operator has measured the engine's net specific energy consumption, in compliance with ASME Performance Test Code PTC 17-1973, at the average load of the engine (see rule for details).

²² Permit includes a 24-month trial period to reduce NOx to the target 0.15 g/bhp-hr. The final NOx BACT level shall be determined by the District after 24 months operating history.

| Table D-24. Manure Digester and Co-Digester Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|--|---|--|--|-----------------------|------------------------------------|---|--|---|--|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 3 | ARB DG Guidance | Waste gas-fired reciprocating engine used in electrical generation (that are required to obtain a district permit) | Lean-burn technology, pre-stratified charge system | BACT | 2002 | 0.6 g/bhp-hr; 50 ppmvd @ 15% O ₂ ; 1.9 lb/MWh | 2.5 g/bhp-hr; 300 ppmvd @ 15% O ₂ ; 7.8 lb/MWh | 0.6 g/bhp-hr; 130 ppmvd @ 15% O ₂ ; 1.9 lb/MWh | N/A | N/A |
| 4 | Chino Basin Desalter Authority; Chino, CA – 2 units | 1,158 bhp manure digester gas- or natural gas-fired IC engine, producing 1.9 MW combined | Lean burn technology, turbocharged and aftercooled, custom engine control, air/fuel module | Permit | | 0.9 g/bhp-hr; 47 ppmv @ 15% O ₂ (@ 32.7% eff.) | 22.7 g/bhp-hr; 2000 ppmv @ 15% O ₂ | 11.3 g/bhp-hr; 325 ppmv @ 15% O ₂ (@ 32.7% eff.) | N/A | N/A |
| 5 | BAAQMD Guideline 96.5.2 | IC engine – digester gas fired, >50 bhp output | Lean burn technology, digester gas pretreatment to remove H ₂ S | BACT (AIP) | 5/14/2009 | 1.25 g/bhp-hr | Initial standard: 2.65 g/bhp-hr Not to exceed standard: 3.77 g/bhp-hr CO emissions based / minimum overhaul schedule | 1.0 g/bhp-hr | 0.3 g/bhp-hr | N/A |
| 6 | BAAQMD Guideline 96.5.2 | IC engine – digester gas fired, >50 bhp output | Digester gas pretreatment w/ >80% H ₂ S removal | BACT (tech. feasible) | 5/14/2009 | 1.0 g/bhp-hr | 2.1 g/bhp-hr | 0.6 g/bhp-hr | N/A | N/A |
| 7 | Gallo Cattle Company; Atwater, CA | 575 bhp Caterpillar Model G399NA rich burn digester gas-fired IC engine, producing 400 kW | 3-way non-selective catalyst, PCV or equivalent, fuel sulfur scrubber | Permit | 9/30/2012 (expiration date) | 9.0 ppmvd @ 15% O ₂ (or 0.15 g/bhp-hr) | 1,100 ppmvd @ 15% O ₂ | 20 ppmvd @ 15% O ₂ as methane | Fuel sulfur limit of 59 ppmv as H ₂ S | 0.1 g/bhp-hr |

| Table D-24. Manure Digester and Co-Digester Gas-Fired Reciprocating Internal Combustion Engine | | | | | | | | | | |
|--|-----------------------------------|---|---|------------------|------------------------------------|---------------------------------|-----------------------------------|----------------------------------|--------------------------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 8 | Gallo Cattle Company; Atwater, CA | 575 bhp Caterpillar Model G399NA rich burn digester gas-fired IC engine, producing 400 kW | 3-way non-selective catalyst, PCV or equivalent, fuel sulfur scrubber | Source test | 1/28/2010 | 3.18 ppmvd @ 15% O ₂ | 384.64 ppmvd @ 15% O ₂ | 11.19 ppmvd @ 15% O ₂ | <1.0 ppm fuel H ₂ S | N/A |

| Table D-25. Biomass Syngas-Fueled Reciprocating Internal Combustion Engine | | | | | | | | | | |
|--|--------------------------|--|----------------------|-----------------------|------------------------------------|------------------------------|-----|-------------------------------|-----------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | SJVAPCD Guideline 3.3.14 | Full-time rich burn IC engine, syngas-fueled ²³ | | BACT (AIP) | 1/12/2009 | 9 ppmvd @ 15% O ₂ | N/A | 25 ppmvd @ 15% O ₂ | N/A | N/A |
| 2 | SJVAPCD Guideline 3.3.14 | Full-time rich burn IC engine, syngas-fueled | | BACT (tech. feasible) | 1/12/2009 | 5 ppmvd @ 15% O ₂ | N/A | N/A | N/A | N/A |

²³ Syngas (synthetic gas) is derived from biomass (agricultural waste) by gasification or similar processes. Syngas is distinguished from waste gases by its low methane content (<5%) and comparatively high hydrogen gas content (15% or greater), although frequently over half of the syngas composition is non-combustible gases such as nitrogen and carbon dioxide.

| Table D-26. Landfill and Sewage Digester Gas-Fired Turbine | | | | | | | | | | |
|--|--|---------------------------------------|----------------------|------------------|------------------------------------|---|--|-----|-----------------|------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 1 | SJVAPCD Rule 4703 Stationary Gas Turbines (Tier 3 standards) | Stationary gas turbines ≥0.3 to 10 MW | | Rule | 9/20/2007 | <p><3 MW: 9 ppmvd @ 15% O₂</p> <p>3-10 MW (pipeline gas): 8 ppmvd @ 15% O₂ (steady state) and 12 ppmvd @ 15% O₂ (non-steady)</p> <p>3-10 MW, <877 hr/yr: 9 ppmvd @ 15% O₂</p> <p>3-10 MW, ≥877 hr/yr: 5 ppmvd @ 15% O₂</p> | 200 ppmvd @ 15% O ₂ ²⁴ | N/A | N/A | N/A |
| 2 | SJVAPCD Rule 4703 Stationary Gas Turbines (Tier 3 standards) | Stationary gas turbines >10 MW | | Rule | 9/20/2007 | <p>Simple cycle and ≤200 hr/yr: 25 ppmvd @ 15% O₂</p> <p>Simple cycle and >200 to 877 hr/yr: 5 ppmvd @ 15% O₂</p> <p>Combined cycle²⁵: 5 ppmvd @ 15% O₂</p> | 200 ppmvd @ 15% O ₂ ²⁶ | N/A | N/A | N/A |

²⁴ Exceptions to CO limit: GE Frame 7 = 25 ppmvd; GE Frame 7 with quiet combustors = 52 ppmvd; and <2.0 MW Solar Saturn driving centrifugal compressor = 250 ppmvd.

²⁵ Tier 2 standard; there is no Tier 3 standard for combined cycle turbines.

²⁶ Exceptions to CO limit: GE Frame 7 = 25 ppmvd; GE Frame 7 with quiet combustors = 52 ppmvd; and <2.0 MW Solar Saturn driving centrifugal compressor = 250 ppmvd.

| Table D-26. Landfill and Sewage Digester Gas-Fired Turbine | | | | | | | | | | |
|--|---|------------------------------------|----------------------|------------------|------------------------------------|--|-----|-----|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 3 | SCAQMD Rule 1134 Emissions of Oxides of Nitrogen from Stationary Gas Turbines | Stationary gas turbines ≥0.3 MW | | Rule | Last amended 8/8/1997 | 0.3-<2.9 MW: 25 ppmvd @ 15% O ₂ 2.9-<10.0 MW ²⁷ : 25 ppmvd @ 15% O ₂ 2.9-<10.0 MW: 9 ppmvd @ 15% O ₂ 2.9-<10.0 MW, no SCR: 15 ppmvd @ 15% O ₂ ≥10 MW: 9 ppmvd @ 15% O ₂ ≥10 MW, no SCR: 12 ppmvd @ 15% O ₂ ≥60 MW, combined cycle, no SCR: 15 ppmvd @ 15% O ₂ ≥60 MW, combined cycle: 9 ppmvd @ 15% O ₂ | N/A | N/A | N/A | N/A |

²⁷ Utilizing fuel containing a minimum of 60% sewage digester gas by volume on a daily average.

| Table D-26. Landfill and Sewage Digester Gas-Fired Turbine | | | | | | | | | | |
|--|---|---|--|------------------|------------------------------------|---|--|---|---|-----------------------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 4 | BAAQMD Guideline 89.3.1 | Gas turbine – landfill gas-fired | Water or steam injection or low-NOx turbine design; fuel selection; good combustion practice; strainer, filter, gas/liquid separator, or equivalent particulate removal device | BACT (AIP) | 6/17/1999 | 25 ppmv @ 15% O ₂ | 200 ppmv @ 15% O ₂ | N/A | 150 ppmv sulfur limit as H ₂ S | Fuel gas pretreatment |
| 5 | ARB DG Guidance ²⁸ | Waste gas-fired turbine rated at <50 MW used in electrical generation (that are required to obtain a district permit) | Water injection | BACT | 2002 | 25 ppmvd @ 15% O ₂ ; 1.25 lb/MWh | N/A | N/A | N/A | N/A |
| 6 | Ameresco Chiquita Energy, LLC; Valencia, CA – 2 units | 53.13 MMBtu/hr landfill gas-fired turbine, simple cycle, producing 4.6 MW each | Ultra lean premix alular combustor, start up LPG augmentation | Permit | | 25 ppmvd @ 15% O ₂ | 130 ppm @ 15% O ₂ | 20 ppmv @ 15% O ₂ as C6 OR 98% destruction | Fuel: 150 ppmv H ₂ S | N/A |
| 7 | Gas Recovery Systems, Inc.; Santee, CA | Landfill gas-fired turbine producing 3.108 MW | | Permit | | 25 ppmvd @ 15% O ₂ | 130 ppmvd @ 15% O ₂ | 3.5 ppmvd @ 15% O ₂ as CH ₄ | 8.3 ppmvd @ 15% O ₂ | N/A |
| 8 | Gas Recovery Systems, Inc.; Santee, CA | Landfill gas-fired turbine producing 3.108 MW | | Source test | 12/1/2006 | 21 ppm @ 15% O ₂ (2.540 MW) | 32 ppm @ 15% O ₂ (2.540 MW) | 3.5 ppm @ 15% O ₂ (2.540 MW) | 2.8 ppm @ 15% O ₂ (2.540 MW) | N/A |

²⁸ Emission level based on the following: Joint Water Pollution Control Plant (Carson).

| Table D-26. Landfill and Sewage Digester Gas-Fired Turbine | | | | | | | | | | |
|--|--|--|---|-----------------------|------------------------------------|--|--|--|--|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 9 | Gas Recovery Systems, Inc.; Santee, CA | Landfill gas-fired turbine producing 3.108 MW | | Source test | 11/23/2004 | 19 ppm @ 15% O ₂ ; (2.642 MW) | 32 ppm @ 15% O ₂ ; (2.642 MW) | 1.6 ppm @ 15% O ₂ ; (2.642 MW) | 2.9 ppm @ 15% O ₂ ; (2.642 MW) | N/A |
| 10 | Los Angeles County Sanitation Districts; Los Angeles, CA | (3) 113 MMBtu/hr Solar Model MARS-90-13000 digester/natural gas-fired combined-cycle turbines with unfired HRSG driving a 5.1 MW steam turbine generator | Water injection (fuel minimum 60% by volume digester gas) | BACT (for NOx and CO) | 9/24/2003 | 25 ppmvd @ 15% O ₂ | 60 ppmvd @ 15% O ₂ | 4.5 lb/hr; 0.04 lb/MMBtu | 1.3 lb/hr; 0.01 lb/MMBtu | 5.7 lb/hr; 0.05 lb/MMBtu |
| 11 | SCAQMD Guidelines for Non-Major Facilities | Digester or landfill gas-fired turbine | | BACT | 1990, 10/20/2000 | 25 ppmvd @ 15% O ₂ | 130 ppmvd @ 15% O ₂ | N/A | Compliance w/ Rule 431.1 | Fuel gas pretreatment for particulate removal |
| 12 | Waste Management; Livermore, CA | (2) 57.4 MMBtu/hr Solar Centaur landfill gas-fired turbines producing 3.33 MW each (Units S-6 and S-7) | | Permit | | 0.1567 lb/MMBtu (38.7 ppmvd @ 15% O ₂) | 0.2229 lb/MMBtu (90.4 ppmvd @ 15% O ₂) | N/A | N/A | N/A |

| Table D-27. Composting | | | | | | | | | | |
|------------------------|--|-----------------------------------|----------------------|------------------|------------------------------------|---------------------|----|--|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SCAQMD Rule 1133.2 Emission Reductions from Co-Composting Operations | Co-composting ²⁹ (new) | | Rule | 1/10/2003 | | | 1. Conduct active composting w/in enclosure; 2. Conduct curing composting phase using aeration system under negative pressure for ≥90% of blower operating cycle; and 3. Vent exhaust from enclosure and aeration system to control device w/ ≥80% VOC and NH ₃ control efficiency. OR Submit alternate plan w/ overall 80% VOC and NH ₃ reduction | | N/A |

²⁹ Co-composting is composting where biosolids and/or manure are mixed with bulking agents to produce compost.

| Table D-27. Composting | | | | | | | | | | |
|------------------------|---|--|----------------------|------------------|------------------------------------|---------------------|----|---|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 2 | SCAQMD Rule 1133.2 Emission Reductions from Co-Composting Operations | Co-composting (existing) ³⁰ | | Rule | 1/10/2003 | | | Submit compliance plan demonstrating overall reduction of 70% VOC and NH ₃ from baseline | | N/A |
| 3 | SJVAPCD Rule 4565 Biosolids, Animal Manure, and Poultry Litter Operations | Composting / co-composting facilities that use ≥100 wet tons per year of biosolids ³¹ , animal manure, or poultry litter as part of their operation | | Rule | 3/15/2007 | | | <u><20,000 wet tons/yr:</u> Implement at least three Class One measures OR Implement at least two Class One and one Class Two measure for active composting <u>≥20,000 to <100,000 wet tons/yr:</u> Implement at least four Class One measures OR Implement at least three Class One and one Class Two measure for active composting | | N/A |

³⁰ Existing operations defined as those that began operations on or before January 1, 2003.

³¹ Organic material from treatment of sewage sludge or wastewater.

| Table D-27. Composting | | | | | | | | | | |
|------------------------|---|---|----------------------|------------------|------------------------------------|---------------------|----|--|-----------------|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| | | | | | | | | ≥100,000 wet tons/yr: Implement at least four Class One and one Class Two measures for active composting OR Implement at least two Class One and one Class Two measures for active composting and one Class Two measure for curing composting | | |
| 4 | Inland Empire Regional Composting Authority; Rancho Cucamonga, CA | Biosolids co-composting operation consisting of enclosed aerated static piles, including materials handling and storage | Biofilter, baghouse | Permit | | | | 80% control (80% control NH ₃) | | No limit in permit, but 99% control expected due to baghouse |

| Table D-27. Composting | | | | | | | | | | |
|------------------------|---|---|----------------------|----------------------|------------------------------------|---------------------|----|---|-----------------|------|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 5 | Los Angeles County Sanitation District (dba Westlake Farms Co-Composting); Mt. Diablo Baseline & Meridian, CA | Co-composting operation consisting of negative aerated static piles, including materials handling and storage | Biofilter | Permit ³² | | | | 80% control (90% control NH ₃) | | N/A |
| 6 | South Kern Industrial Center, LLC; Taft, CA | Biosolids co-composting operation consisting of negative aerated static piles, including materials handling and storage | Biofilter | Permit ³³ | | | | 80% control (80% control NH ₃) | | N/A |

³² ARB staff received a draft copy of the permit; however correspondence with the District indicates the permit has been issued.

³³ ARB staff received a draft copy of the permit; however correspondence with the District indicates the permit has been issued.

| Table D-28. Emergency Diesel Reciprocating Internal Combustion Engine | | | | | | | | | | |
|---|--|---|----------------------|--|------------------------------------|--|--|--|--|---|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| 1 | SJVAPCD Guideline 3.1.1 | Emergency diesel IC engine | | BACT (AIP) | 7/10/2009 | Latest EPA Tier Certification level for applicable hp range | Latest EPA Tier Certification level for applicable hp range | Latest EPA Tier Certification level for applicable hp range | Very low sulfur diesel fuel (15 ppmw sulfur or less) | 0.15 g/bhp-hr or latest EPA Tier Certification level for applicable hp range, whichever is more stringent |
| 2 | ATCM for Stationary Compression Ignition Engines | New stationary emergency standby diesel-fueled compression ignition engines >50 bhp – non-emergency use limited to 50 hr/yr | | Regulation (title 17 CCR sections 93115 to 93115.15) | 10/18/2007 | Off-road compression ignition engine standards for an off-road engine of the model year and bhp rating of the engine stalled to meet the applicable PM standard, or Tier 1 standards ³⁴ | Off-road compression ignition engine standards for an off-road engine of the model year and bhp rating of the engine stalled to meet the applicable PM standard, or Tier 1 standards | Off-road compression ignition engine standards for an off-road engine of the model year and bhp rating of the engine stalled to meet the applicable PM standard, or Tier 1 standards | CARB diesel (15 ppmw sulfur or less) | 0.15 g/bhp-hr |

³⁴ The option to comply with the Tier 1 standards is available only if no off-road engine certification standards have been established for an off-road engine of the same model year and maximum rated power as the new stationary emergency standby diesel-fueled compression ignition engine.

Table D-28. Emergency Diesel Reciprocating Internal Combustion Engine

| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
|----------|---|---|----------------------|--|------------------------------------|--|---|--|---|--|
| | | | | | | NOx | CO | VOC | SO ₂ | PM ₁₀ |
| 3 | ATCM for Stationary Compression Ignition Engines | New stationary emergency standby diesel-fueled compression ignition engines >50 bhp – non-emergency use limited to 51-100 hr/yr | | Regulation (title 17 CCR sections 93115 to 93115.15) | 10/18/2007 | Off-road compression ignition engine standards for an off-road engine of the model year and bhp rating of the engine stalled to meet the applicable PM standard, or Tier 1 standards ³⁵ | Off-road compression ignition engine standards for an off-road engine of the model year and bhp rating of the engine stalled to meet the applicable PM standard, or Tier 1 standards | Off-road compression ignition engine standards for an off-road engine of the model year and bhp rating of the engine stalled to meet the applicable PM standard, or Tier 1 standards | CARB diesel (15 ppmw sulfur or less) | 0.01 g/bhp-hr |
| 4 | SCAQMD BACT Guidelines for Non-Major Polluting Facilities | IC Engine, Stationary, Emergency, Compression-Ignition, Other | | BACT | 10/3/2008 | <p>50≤hp<100: 4.7 g/kWh or 3.5 g/bhp-hr (Tier 3)³⁶</p> <p>100≤hp<175: 4.0 g/kWh or 3.0 g/bhp-hr (Tier 3)</p> <p>175≤hp<300: 4.0 g/kWh or 3.0 g/bhp-hr (Tier 3)</p> <p>300≤hp<750: 4.0 g/kWh or 3.0 g/bhp-hr</p> | <p>50≤hp<100: 5.0 g/kWh or 3.7 g/bhp-hr (Tier 3)</p> <p>100≤hp<175: 5.0 g/kWh or 3.7 g/bhp-hr (Tier 3)</p> <p>175≤hp<300: 3.5 g/kWh or 2.6 g/bhp-hr (Tier 3)</p> <p>300≤hp<750: 3.5 g/kWh or 2.6 g/bhp-hr</p> | <p>50≤hp<100: 4.7 g/kWh or 3.5 g/bhp-hr (Tier 3)³⁷</p> <p>100≤hp<175: 4.0 g/kWh or 3.0 g/bhp-hr (Tier 3)</p> <p>175≤hp<300: 4.0 g/kWh or 3.0 g/bhp-hr (Tier 3)</p> <p>300≤hp<750: 4.0 g/kWh or 3.0 g/bhp-hr</p> | On or after June 1, 2004, the user may only purchase diesel fuel with a sulfur content no greater than 0.0015% by weight (Rule 431.2) | <p>50≤hp<100: 0.40 g/kWh or 0.30 g/bhp-hr (Tier 3)</p> <p>100≤hp<175: 0.30 g/kWh or 0.22 g/bhp-hr (Tier 3)</p> <p>175≤hp<300: 0.20 g/kWh or 0.15 g/bhp-hr (Tier 3)</p> <p>300≤hp<750: 0.20 g/kWh or 0.15</p> |

³⁵ The option to comply with the Tier 1 standards is available only if no off-road engine certification standards have been established for an off-road engine of the same model year and maximum rated power as the new stationary emergency standby diesel-fueled compression ignition engine.

³⁶ These are all NOx+NMHC standards.

³⁷ These are all NOx+NMHC standards.

| Table D-28. Emergency Diesel Reciprocating Internal Combustion Engine | | | | | | | | | | |
|---|----------------------------|--|---|------------------|------------------------------------|--|--|--|--|--|
| Ref. No. | Facility Name | Basic Equipment | Method(s) of Control | Type of Document | Date of BACT Det., Permit, or Rule | Emissions, per unit | | | | |
| | | | | | | NOx | CO | VOC | SO ₂ | PM10 |
| | | | | | | (Tier 3) | (Tier 3) | (Tier 3) | | g/bhp-hr (Tier 3) |
| | | | | | | ≥750 hp: 6.4 g/kWh or 4.8 g/bhp-hr (Tier 2) | ≥750 hp: 3.5 g/kWh or 2.6 g/bhp-hr (Tier 2) | ≥750 hp: 6.4 g/kWh or 4.8 g/bhp-hr (Tier 2) | | ≥750 hp: 0.20 g/kWh or 0.15 g/bhp-hr (Tier 2) |
| 5 | BAAQMD Guideline 96.1.3 | IC Engine – Compression Ignition: Stationary Emergency, non- Agricultural, non- direct drive fire pump, >50 bhp output | Any engine certified or verified to achieve the applicable standard, CARB diesel fuel (ultra low sulfur diesel) | BACT (AIP) | 4/13/2009 | Current Tier standard for NOx at applicable horsepower rating | More stringent of either 2.75 g/bhp-hr (319 ppmvd @ 15% O ₂) or the current Tier standard | Current Tier standard for POC at applicable horsepower rating | Fuel sulfur content not to exceed 0.0015% (wt) or 15 ppm | More stringent of either 0.15 g/bhp-hr or the current Tier standard |

| Engine hp (kW) | Tier 1 ³⁹ | | | | | Tier 2 | | | | Tier 3 | | | | Tier 4 | | | | | |
|----------------------------|----------------------|--------------|---------------|---------------|----------------|---------------|--------------|----------------|----------------|---------------|--------------|----------------|----------------|---------------|----------------|--------------------------------|--------------|-----------------|----------------|
| | HC | NOx | CO | PM | Years | NMHC + NOx | CO | PM | Years | NMHC + NOx | CO | PM | Years | NMHC + NOx | NMHC | NOx | CO | PM | Years |
| 50 - <75 (37 - <56) | | 6.9 (9.2) | | | 1998 – 2003 | 5.6 (7.5) | 3.7 (5.0) | 0.30 (0.40) | 2004 – 2007 | 3.5 (4.7) | 3.7 (5.0) | 0.22 (0.30) | 2008 – 2012 | 3.5 (4.7) | | | 3.7 (5.0) | 0.02 (0.03) | 2013+ |
| 75 - <100 (56 - <75) | | 6.9 (9.2) | | | 1998 – 2003 | 5.6 (7.5) | 3.7 (5.0) | 0.30 (0.40) | 2004 – 2007 | 3.5 (4.7) | 3.7 (5.0) | 0.30 (0.40) | 2008 – 2011 | 3.5 (4.7) | 0.14 (0.19) | 0.30- 2.5 (0.40- 3.4) | 3.7 (5.0) | 0.01 (0.02) | 2012 - 2013 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.30 (0.40) | 3.7 (5.0) | 0.01 (0.02) | 2014+ |
| 100 - <175 (75 - <130) | | 6.9 (9.2) | | | 1997 - 2002 | 4.9 (6.6) | 3.7 (5.0) | 0.22 (0.30) | 2003 – 2006 | 3.0 (4.0) | 3.7 (5.0) | 0.22 (0.30) | 2007 – 2011 | 3.0 (4.0) | 0.14 (0.19) | 0.30- 2.5 (0.40- 3.4) | 3.7 (5.0) | 0.01 (0.02) | 2012 - 2013 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.30 (0.40) | 3.7 (5.0) | 0.01 (0.02) | 2014+ |
| 175 - <300 (130 - <225) | 0.97 (1.3) | 6.9 (9.2) | 8.5 (11.4) | 0.4 (0.54) | 1996 – 2002 | 4.9 (6.6) | 2.6 (3.5) | 0.15 (0.20) | 2003 – 2005 | 3.0 (4.0) | 2.6 (3.5) | 0.15 (0.20) | 2006 – 2010 | 3.0 (4.0) | 0.14 (0.19) | 0.30- 1.5 (0.40- 2.0) | 2.6 (3.5) | 0.01 (0.02) | 2011 – 2013 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.30 (0.40) | 2.6 (3.5) | 0.01 (0.02) | 2014+ |
| 300 - <600 (225 - <450) | 0.97 (1.3) | 6.9 (9.2) | 8.5 (11.4) | 0.4 (0.54) | 1996 – 2000 | 4.8 (6.4) | 2.6 (3.5) | 0.15 (0.20) | 2001 – 2005 | 3.0 (4.0) | 2.6 (3.5) | 0.15 (0.20) | 2006 – 2010 | 3.0 (4.0) | 0.14 (0.19) | 0.30- 1.5 (0.40- 2.0) | 2.6 (3.5) | 0.01 (0.02) | 2011 – 2013 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.30 (0.40) | 2.6 (3.5) | 0.01 (0.02) | 2014+ |
| 600 - <750 (450 - <560) | 0.97 (1.3) | 6.9 (9.2) | 8.5 (11.4) | 0.4 (0.54) | 1996 – 2001 | 4.8 (6.4) | 2.6 (3.5) | 0.15 (0.20) | 2002 – 2005 | 3.0 (4.0) | 2.6 (3.5) | 0.15 (0.20) | 2006 – 2010 | 3.0 (4.0) | 0.14 (0.19) | 0.30- 1.5 (0.40- 2.0) | 2.6 (3.5) | 0.01 (0.02) | 2011 – 2013 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.30 (0.40) | 2.6 (3.5) | 0.01 (0.02) | 2014+ |
| ≥750 (≥560) | 0.97 (1.3) | 6.9 (9.2) | 8.5 (11.4) | 0.4 (0.54) | 2000 – 2005 | 4.8 (6.4) | 2.6 (3.5) | 0.15 (0.20) | 2006 – 2010 | | | | | | 0.30 (0.40) | 2.6 (3.5) | 2.6 (3.5) | 0.075 (0.10) | 2011 – 2014 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 2.6 (3.5) | 2.6 (3.5) | 0.03 (0.04) | 2015+ |

³⁸ For California Exhaust Emission Standards and Test Procedures – Off-Road Compression-Ignition Engines, see title 13, California Code of Regulations, section 2423. For federal Nonroad Compression-Ignition Engine Certification Standards, consult title 40, United States Code of Federal Regulations, Chapter 1, Part 89, Subpart B and Part 1039, Subpart B.

³⁹ Engine manufacturers have several options for complying with NOx during the transitional implementation years of Tier 4, including a “phase-in/phase-out” or alternative NOx level approach.

| Table D-29. Off-Road Compression Ignition Engine Certification Standards in g/bhp-hr (g/kW-hr) ³⁸ | | | | | | | | | | | | | | | | | | | |
|--|----------------------|--------------|---------------|---------------|----------------|---------------|--------------|----------------|----------------|---------------|----|----|-------|---------------|----------------|----------------|--------------|-----------------|----------------|
| Engine hp (kW) | Tier 1 ³⁹ | | | | | Tier 2 | | | | Tier 3 | | | | Tier 4 | | | | | |
| | HC | NOx | CO | PM | Years | NMHC + NOx | CO | PM | Years | NMHC + NOx | CO | PM | Years | NMHC + NOx | NMHC | NOx | CO | PM | Years |
| >750 - ≤1200 (560 - ≤900) Gen. only | 0.97 (1.3) | 6.9 (9.2) | 8.5 (11.4) | 0.4 (0.54) | 2000 – 2005 | 4.8 (6.4) | 2.6 (3.5) | 0.15 (0.20) | 2006 – 2010 | | | | | | 0.30 (0.40) | 2.6 (3.5) | 2.6 (3.5) | 0.075 (0.10) | 2011 – 2014 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.50 (0.67) | 2.6 (3.5) | 0.02 (0.03) | 2015+ |
| >1200 (>900) Gen. only | 0.97 (1.3) | 6.9 (9.2) | 8.5 (11.4) | 0.4 (0.54) | 2000 – 2005 | 4.8 (6.4) | 2.6 (3.5) | 0.15 (0.20) | 2006 – 2010 | | | | | | 0.30 (0.40) | 0.50 (0.67) | 2.6 (3.5) | 0.075 (0.10) | 2011 – 2014 |
| | | | | | | | | | | | | | | | 0.14 (0.19) | 0.50 (0.6) | 2.6 (3.5) | 0.02 (0.03) | 2015+ |